



Louisville and Jefferson County Metropolitan Sewer District  
700 West Liberty Street  
Louisville Kentucky 40203-1911  
502-540-6000  
www.msdlouky.org

Aug 19, 2015

Cheryl Edwards  
DMR Coordinator  
200 Fair Oaks Lane  
Frankfort, Kentucky 40601

**Re: MSD Metro Operations  
Timber Lake WQTC; KPDES No.: KY 0043087  
Discharge Monitoring Report for July 2015**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operator Report (MOR) for the Timber Lake WQTC; KPDES No.: KY0043087 for the month of July.

This plant stopped discharging flow on July 7, 2015. MSD personnel emailed a No Discharge Certification letter to Ann Workman on July 12, 2015.

There were no overflow, exceedences or bypasses reports for the month of July.

If you have any questions concerning the attached DMRs, please contact me at (502) 540-6031.

Sincerely,

John Kessel  
Process Supervisor, West region

JK/ Timberlake 7/15

Enclosures

CC T. Singleton  
R. Shaw  
C. Roth



Beneficial Use of Louisville's Biosolids  
www.louisvillegreen.com



51040	E. coli	1 - Effluent Gross	0	--	Sample	=	1	=	1	13 - #/100mL	0	01/30 - Monthly	GR - GRAB				
					Permit Req.			<=	130 30DA GEO	<=		240 7 DA GEO	13 - #/100mL	01/07 - Weekly	GR - GRAB		
					Value NODI												
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	2.3	=	2	26 - lb/d	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.	<=	16.7 30DA AVG	<=	25 DAILY MX	<=		10 30DA AVG	<=	15 DAILY MX	19 - mg/L	01/07 - Weekly	24 - COMP24
					Value NODI												

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
Timberlake_MOR_072015.pdf	pdf	22637
Timberlake_cover_072015.pdf	pdf	48284

**Report Last Saved By**

**TIMBERLAKE WQTC MSD**

User: kevin.ries@louisvillemmsd.org  
 Name: Kevin Ries  
 E-Mail: kevin.ries@louisvillemmsd.org

Date/Time: 2015-08-21 09:26 (Time Zone: -04:00)

Timberlake

Timberlake		Report	Jul-15			Tot. Exc.	0 (Influent data below.)									
Tot. Flow=		0.70322		Concentrations			Pounds									
Date	Flow	TSS	BOD	NH3	ECOLI	TSS	BOD	NH3	Tot. Phos.	Tot. N	TSS Rem	BOD Rem	D.O.	p.H.	TRC	
7/1/15	0.091	8	3	0.56		6.080	2.280	0.43	0.60	20.26	0.98	0.99	7.4	7.1	0.01	
7/2/15	0.102				1								7.5	7.1	0.01	
7/3/15	0.100												7.5	7.2	0.01	
7/4/15	0.091												7.6	7.1	0.01	
7/5/15	0.097												7.4	7.2	0.01	
7/6/15	0.091												7.6	7.1	0.01	
7/7/15	0.061															
7/8/15	0.071															
7/9/15																
7/10/15																
7/11/15																
7/12/15																
7/13/15																
7/14/15																
7/15/15																
7/16/15																
7/17/15																
7/18/15																
7/19/15																
7/20/15																
7/21/15																
7/22/15																
7/23/15																
7/24/15																
7/25/15																
7/26/15																
7/27/15																
7/28/15																
7/29/15																
7/30/15																
7/31/15																
Average	0.088	8	3	0.6	1.00	6	2.280	0.43	0.6	20.26	98%	99%	7.50	7	0.01	
Maximum	0.102	8	3	0.6	1.00	6	2.280	0.4	0.6	20.26			7.60	7	0.01	
Exceed.	0	0	0	0	0	0	0	0			0	0				