



Safe, clean waterways

700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.587.0603 | Fax: 502.540.6106 | louisvillemsd.org

November 9, 2021

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420  
Discharge Monitoring Report for October 2021.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of October 2021.

There were no bypasses, overflows or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Staci Huber  
Process Supervisor

SH/ Hite Creek. 10/21.

Cc: V. Teague  
R. Shaw



80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample	=	98.0							23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN						23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI											
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	98.0							23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN						23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI											

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
HCMOR1021.pdf	pdf	153057.0
HCCoverletter.pdf	pdf	33057.0

**Report Last Saved By**

**Hite Creek WQTC MSD**

User: staci.huber@louisvillemmsd.org  
 Name: Staci Huber  
 E-Mail: staci.huber@louisvillemmsd.org  
 Date/Time: 2021-11-22 10:26 (Time Zone: -05:00)

**Report Last Signed By**

User: staci.huber@louisvillemmsd.org  
 Name: Staci Huber  
 E-Mail: staci.huber@louisvillemmsd.org  
 Date/Time: 2021-11-22 10:26 (Time Zone: -05:00)

