



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

January 12, 2022

Crystal Dennis
Permit Support Section
Surface Water Permits Branch
Division of Water
200 Fair Oaks Lane, 4th floor
Frankfort, KY 40601

Subject: Bullitt Co Sewer District, November DMR's

Dear Ms. Dennis:

On behalf of the Bullitt County Sewer District (BCSD), which dissolved on December 1, 2021, when Louisville MSD took ownership. I will be submitting the following plants Discharge Monitoring Reports for the reporting period of November 1 through November 30, 2021. The submittal of the DMR's is being completed in good faith effort to keep the regulatory reports current and up to date with the Division of water.

Please understand that during this monitoring period no one at Louisville MSD had any control over these plants, performed any operational activities or performed any of the regulated discharge sampling. BCSD employees were primarily responsible for operational control during this reporting period. In addition Beckmar Environmental Laboratory completed the regulatory field sampling and entered the data into Net DMR.

KY0103900 Hillview WWTP (Prologis)
KY0034185 Pioneer Village
KY0034169 Hillview #2
KY0034151 Hillview #1
KY0034801 Bullitt Hills
KY0034177 Hillview #3
KY0094307 Willabrook
KY0072168 Big Valley

Should you have any additional questions, please contact me at (502) 540-6222 or john.kessel@louisvillemsd.org.

Sincerely,

John Kessel
Assistant Director of Treatment Facilities

JMK / BCSD / 012022

cc: B. Tinnell
RecordsRequest@louisvillemsd.org

DMR Copy of Record

Permit			
Permit #:	KY0034177	Permittee:	Louisville and Jefferson County MSD
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
Facility:		Facility Location:	BCSD HILLVIEW #3 12325 WESTERN RD HILLVIEW, KY 40129

Report Dates & Status			
Monitoring Period:	From 11/01/21 to 11/30/21	DMR Due Date:	12/28/21
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	Jerry	Title:	BCSD
Last Name:	Kennedy	Telephone:	502-957-6140

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	7.3					19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.91			=	7.56	12 - SU	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/07 - Weekly	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample					=	10.0			=	21.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	30.0 MO AVG			<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample					=	11.0			=	13.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.											19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample					=	6.5			=	8.4	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	10.0 MO AVG			<=	15.0 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample					=	1.9			=	2.6	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.											19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.233	=	0.233								0	99/99 - Continuous	RC - Recorder (auto)	
					Permit Req.														99/99 - Continuous	RC - Recorder (auto)
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	0.01			=	0.01	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					<=	0.011 MO AVG			<=	0.019 DAILY MX	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample					=	6.0			=	62.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					<=	130.0 30DA GEO			<=	240.0 7 DA GEO	13 - #/100mL		01/07 - Weekly	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample					=	9.0			=	14.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	15.0 MO AVG			<=	22.5 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size

Report Last Saved By

Louisville and Jefferson County MSD

User: kessel@louisvillemd.org
Name: John Kessel
E-Mail: kessel@louisvillemd.org
Date/Time: 2022-01-12 13:09 (Time Zone: -05:00)

Report Last Signed By

User: kessel@louisvillemd.org
Name: John Kessel
E-Mail: kessel@louisvillemd.org
Date/Time: 2022-01-12 13:10 (Time Zone: -05:00)