



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

May 19th, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Bullitt Hills STP, KPDES No: KY0034801
Discharge Monitoring Report for April 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Bullitt Hills STP, for the month April 2022.

There were no overflows or bypasses

There was one exceedance on Nitrogen Ammonia Daily Maximum limit of 15.0 mg/l, with a result of 23.0 mg/l. This was due to a prolonged rain event that forced us to make adjustments to the plant to accommodate high flow.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith
Process Supervisor

JSS/ BH 04/22.

Cc: V. Teague

DMR Copy of Record

Permit		Permit #: KY0034801		Permittee: Louisville and Jefferson County MSD		Facility: BCSD BULLITT HILLS SUBDIVISION	
Major: No		Permittee Address: 700 W Liberty St Louisville, KY 40203		Facility Location: 12105 PRESTON HWY HILLVIEW, KY 40229			
Permitted Feature: 001 External Outfall		Discharge: 001-1 Domestic Wastewater					

Report Dates & Status			
Monitoring Period: From 04/01/22 to 04/30/22	DMR Due Date: 05/28/22	Status:	NetDMR Validated

Considerations for Form Completion

Principal Executive Officer			
First Name: James	Title: Executive Director	Telephone: 502-540-6000	
Last Name: Parrott			

No Data Indicator (NODI)			
Form NODI: --			

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	7.0					19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.91			=	7.47	12 - SU	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/07 - Weekly	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample					=	15.0			=	43.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	30.0 MO AVG			<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample					=	14.0			=	21.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.											19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
X 00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample					=	7.0			=	23.0	19 - mg/L	1	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	10.0 MO AVG			<=	15.0 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample					=	2.2			=	5.5	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.											19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.288	=	0.701								0	01/07 - Weekly	IN - INSTAN	
					Permit Req.														01/07 - Weekly	IN - INSTAN
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					=	0.01			=	0.01	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					<=	0.011 MO AVG			<=	0.019 DAILY MX	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample					<	1.0			<	1.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					<=	130.0 30DA GEO			<=	240.0 7 DA GEO	13 - #/100mL		01/07 - Weekly	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample					=	11.0			=	24.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	25.0 MO AVG			<=	37.5 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors						
Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments

Attachments

Name	Type	Size
BHCCoverLetter.pdf	pdf	37242.0

Report Last Saved By

Louisville and Jefferson County MSD

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
Name: Joseph Smith
E-Mail: joseph.smith@louisvillemmsd.org
Date/Time: 2022-05-20 08:36 (Time Zone: -04:00)

Report Last Signed By

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
Name: Joseph Smith
E-Mail: joseph.smith@louisvillemmsd.org
Date/Time: 2022-05-20 08:37 (Time Zone: -04:00)