



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

September 26th, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Bullitt Hills STP, KPDES No: KY0034801
Discharge Monitoring Report for August 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Bullitt Hills STP, for the month August 2022.

There were no overflows, bypasses or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith
Process Supervisor

JSS/ BH 08/22.

Cc: V. Teague / B. Tinnell

DMR Copy of Record

Permit			
Permit #:	KY0034801	Permittee:	Louisville and Jefferson County MSD
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
Facility:	BCSD BULLITT HILLS SUBDIVISION		
Facility Location:	12105 PRESTON HWY HILLVIEW, KY 40229		

Report Dates & Status			
Monitoring Period:	From 08/01/22 to 08/31/22	DMR Due Date:	09/28/22
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	James	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.0					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.04					12 - SU	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM					12 - SU		01/07 - Weekly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample							<	6.0				19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.						<=	30.0 MO AVG					19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample							=	11.0				19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.							Req Mon MO AVG					19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample							=	0.3				19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.						<=	4.0 MO AVG					19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample							=	2.7				19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.							Req Mon MO AVG					19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.245	=	0.5666	03 - MGD								0	01/07 - Weekly	IN - INSTAN
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									01/07 - Weekly	IN - INSTAN
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample							<	0.01				19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						<=	0.011 MO AVG					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample							=	8.0				13 - #/100mL	0	01/07 - Weekly	GR - GRAB
					Permit Req.						<=	130.0 30DA GEO					13 - #/100mL		01/07 - Weekly	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample							=	6.0				19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.						<=	25.0 MO AVG					19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
------	------	------

Report Last Saved By

Louisville and Jefferson County MSD

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
Name: Joseph Smith
E-Mail: joseph.smith@louisvillemSD.org
Date/Time: 2022-09-26 12:20 (Time Zone: -04:00)

Report Last Signed By

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
Name: Joseph Smith
E-Mail: joseph.smith@louisvillemSD.org
Date/Time: 2022-09-26 12:21 (Time Zone: -04:00)