



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

November 11th, 2022

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Bullitt Hills STP, KPDES No: KY0034801  
Discharge Monitoring Report for October 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Bullitt Hills STP, for the month October 2022.

There were no overflows or bypasses

There were three exceedances for the Month of October, Nitrogen Ammonia Monthly Avg limit of 4.0 mg/l with a result of 9.6 mg/l, a Nitrogen Ammonia Daily Maximum limit of 6.0 mg/l with a result of 19.6 mg/l, Total Suspended Solids Maximum Weekly Average limit of 45.0 mg/l with a result of 47.0 mg/l.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith  
Process Supervisor

JSS/ BH 10/22.

Cc: V. Teague / B. Tinnell

DMR Copy of Record

<b>Permit</b>						
Permit #:	KY0034801	Permittee:	Louisville and Jefferson County MSD		Facility:	BCSD BULLITT HILLS SUBDIVISION
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203		Facility Location:	12105 PRESTON HWY HILLVIEW, KY 40229
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater			

<b>Report Dates &amp; Status</b>					
Monitoring Period:	From 10/01/22 to 10/31/22	DMR Due Date:	11/28/22	Status:	NetDMR Validated

<b>Considerations for Form Completion</b>					
-------------------------------------------	--	--	--	--	--

<b>Principal Executive Officer</b>					
First Name:	James	Title:	Executive Director	Telephone:	502-540-6000
Last Name:	Parrott				

<b>No Data Indicator (NODI)</b>					
Form NODI:	--				

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	7.1					19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.92			=	7.63	12 - SU	0	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/07 - Weekly	GR - GRAB	
					Value NODI															
X 00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample					=	21.0			=	47.0	19 - mg/L	1	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	30.0 MO AVG			<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample					=	34.0			=	36.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.											19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
X 00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample					=	9.6			=	19.6	19 - mg/L	2	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	4.0 MO AVG			<=	6.0 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample					=	5.9			=	7.7	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.											19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.191	=	0.233								0	01/07 - Weekly	IN - INSTAN	
					Permit Req.														01/07 - Weekly	IN - INSTAN
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					<	0.01			<	0.01	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.													19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample					=	1.0			=	1.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB	
					Permit Req.													13 - #/100mL	01/07 - Weekly	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample					=	13.0			=	25.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.													19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI															

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

<b>Edit Check Errors</b>						
Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

00530 Solids, total suspended 1 - Effluent Gross Quality or Concentration Sample Value 3 Soft The provided sample value is outside the permit limit. Please verify that the value you have provided is correct. Yes

**Comments**

**Attachments**

Name	Type	Size
BHCoverletter.pdf	pdf	38674.0

**Report Last Saved By**

**Louisville and Jefferson County MSD**

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG  
Name: Joseph Smith  
E-Mail: joseph.smith@louisvillemSD.org  
Date/Time: 2022-11-16 09:51 (Time Zone: -05:00)

**Report Last Signed By**

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG  
Name: Joseph Smith  
E-Mail: joseph.smith@louisvillemSD.org  
Date/Time: 2022-11-16 09:51 (Time Zone: -05:00)