



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

May 13, 2022

Ms. Crystal Dennis
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: Derek Guthrie Water Quality Treatment Center
KPDES Permit No. KY0078956,
Discharge monitoring report for April 2022.**

Dear Ms. Crystal Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Derek Guthrie WQTC, KPDES No: KY0078956, for the month of April 2022.

There were no bypasses or exceedances for the Derek Guthrie WQTC.

Also attached are overflow reports.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.
Sincerely,

Kevin Thompson
Process Supervisor, West Region

KLT/West County 04/22

Enclosures

cc: B. Tinnell
V. Graves
M. Saylor



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLSSewer Lift Station	MSD0101-PS	9317 LANTANA DR	DEREK R. GUTHRIE	PENNSYLVANIA RUN	DITCH

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	3498020		04/13/2022	CATALANO JR	BROWN JR	DOCUMENTE D	03/18/2013	POWER OUTAGE (LG&E)	UNAUTHORIZED DISCHARGE-	04/14/22 12:15 AM	

Discharge Reporting:

Discharge Amount:	2,200 GAL
Cause:	POWER OUTAGE (LG&E).
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	GENERATOR UTILIZED UNTIL POWER RESTORED.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

4/14/22 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
4/14/22 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLSSewer Lift Station	MSD1013-PS	9114 CINDERELLA LN	DEREK R. GUTHRIE	FISHPOOL CREEK	DITCH

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	3498018		04/13/2022	CATALANO JR WILLETT		REPAIRED - ISSUE RESOLVED	04/13/2022	POWER OUTAGE (LG&E)	UNAUTHORIZED DISCHARGE-WATERS	04/13/22 12:00 PM	

Discharge Reporting:

Discharge Amount:	6,750 GAL
Cause:	POWER OUTAGE (LG&E).
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	GENERATOR UTILIZED UNTIL POWER RESTORED.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

4/14/22 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
4/14/22 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION