



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

May 24, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for April 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Floyds Fork Water Quality Treatment Center for the month of April 2022.

There were no bypasses, discharges, or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6952.

Sincerely,

William Ford
Process Supervisor-Operations

WEF/ Floyds Fork 05/22

Cc: V. Teague
B. Tinnel

81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	99.0										23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.	>=	85.0 MO AV MN										23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
FFCoverletter042022.pdf	pdf	33346.0
FFMOR042022.pdf	pdf	193199.0

Report Last Saved By

Floyds Fork WQTC MSD

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
 Name: Joseph Smith
 E-Mail: joseph.smith@louisvillemmsd.org
 Date/Time: 2022-05-24 14:13 (Time Zone: -04:00)

Report Last Signed By

User: WILLIAM.FORD@LOUISVILLEMSD.ORG
 Name: William Ford
 E-Mail: william.ford@louisvillemmsd.org
 Date/Time: 2022-05-24 14:29 (Time Zone: -04:00)

NAME OF TREATMENT PLANT Floyds Fork COUNTY Jefferson

Month of: April 2022

Avg. Flow:

4.42

Sludge Disposal

Date	Rainfall	in Gallons	Remarks
1	0	39600	
2	0	0	
3	0	0	
4	0.02	36000	
5	0.54	28800	
6	1	50400	
7	0	36000	
8	0.21	39600	
9	0.05	0	
10	0	0	
11	0.49	36000	
12	0.08	61200	
13	0.95	61200	
14	0.11	36000	
15	0.02	43200	
16	0	0	
17	0	0	
18	0.34	57600	
19	0	46800	
20	0	61200	
21	0.33	94500	
22	0	100800	
23	0	0	
24	0	0	
25	0.02	94500	
26	0	94500	
27	0	63000	
28	0	113400	
29	0	56700	
30	0.01	0	
31		0	