



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

December 19th, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hillview #2 STP, KPDES No: KY00034169
Discharge Monitoring Report for November 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview #2 WQTC, for the month November 2022.

There were no overflows, exceedances or bypasses

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith
Process Supervisor

JSS/ HV#2 11/22.

Cc: V. Teague /B. Tinnell

DMR Copy of Record

Permit			
Permit #:	KY0034169	Permittee:	Hillview Sewer System Plant 2
Major:	No	Permittee Address:	PO Box 818 Hillview, KY 40129
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
Facility:	BCSD HILLVIEW #2	Facility Location:	376 NORWOOD WAY HILLVIEW, KY 40229

Report Dates & Status			
Monitoring Period:	From 11/01/22 to 11/30/22	DMR Due Date:	12/28/22
Status:	NetDMR Validated		

Considerations for Form Completion			
---	--	--	--

Principal Executive Officer			
First Name:	James	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)			
Form NODI:	--		

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.76					19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.						>=	7.0 INST MIN						19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.59			=	8.0	12 - SU	01/07 - Weekly	GR - GRAB	
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU	01/07 - Weekly	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								=	18.0	=	29.0	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.							<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	33.7	=	43.7	19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.															
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample								=	1.38	=	4.2	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.															
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	5.0	=	7.2	19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.															
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.149	=	0.47	03 - MGD								01/07 - Weekly	IN - INSTAN	
					Permit Req.															
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								<	0.01	<	0.01	19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.															
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								<	1.0	<	1.0	13 - #/100mL	01/07 - Weekly	GR - GRAB	
					Permit Req.															
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample								=	8.0	=	11.0	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.															
					Value NODI															

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments		
Name	Type	Size

Report Last Saved By

Hillview Sewer System Plant 2

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
Name: Joseph Smith
E-Mail: joseph.smith@louisvillemsd.org
Date/Time: 2022-12-19 12:32 (Time Zone: -05:00)

Report Last Signed By

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
Name: Joseph Smith
E-Mail: joseph.smith@louisvillemsd.org
Date/Time: 2022-12-19 12:33 (Time Zone: -05:00)