



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

April 20th, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Pro Logics STP, KPDES No: KY0103900
Discharge Monitoring Report for March 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Pro Logics STP, for the month March 2022.

There were no overflows or bypasses.

Due to a Blower failure we had two exceedances for the month of March. A Nitrogen Ammonia Monthly Average limit of 8.0 mg/l had an exceedance result of 8.9 mg/l and a Nitrogen Ammonia Daily Maximum limit of 12.0 mg/l had an exceedance result of 17.9 mg/l.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith
Process Supervisor

JSS/ PRO LOG 03/22.

Cc: V. Teague
R. Shaw

81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample												95.0				23 - %		01/30 - Monthly	CA - CALCTD				
					Permit Req.																				23 - %		01/30 - Monthly	CA - CALCTD
					Value NODI																							

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments

Attachments

Name	Type	Size
ProLogCoverleter0322.pdf	pdf	38277.0

Report Last Saved By

Louisville and Jefferson County MSD

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
 Name: Joseph Smith
 E-Mail: joseph.smith@louisvillemSD.org
 Date/Time: 2022-04-21 10:38 (Time Zone: -04:00)

Report Last Signed By

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
 Name: Joseph Smith
 E-Mail: joseph.smith@louisvillemSD.org
 Date/Time: 2022-04-21 10:39 (Time Zone: -04:00)