



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

May 19th, 2022

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Pro Logics STP, KPDES No: KY0103900  
Discharge Monitoring Report for April 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Pro Logics STP, for the month April 2022.

There were no exceedances, overflows or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith  
Process Supervisor

JSS/ PRO LOG 04/22.

Cc: V. Teague  
R. Shaw



81011	<b>Solids, suspended percent removal</b>	K - Percent Removal	0	--	Sample	=	86.0							23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN							23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI											

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
ProLogCoverLetter.pdf	pdf	32908.0

**Report Last Saved By**

**Louisville and Jefferson County MSD**

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG  
 Name: Joseph Smith  
 E-Mail: joseph.smith@louisvillemmsd.org  
 Date/Time: 2022-05-20 08:38 (Time Zone: -04:00)

**Report Last Signed By**

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG  
 Name: Joseph Smith  
 E-Mail: joseph.smith@louisvillemmsd.org  
 Date/Time: 2022-05-20 08:39 (Time Zone: -04:00)