



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

August 22nd, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Pro Logics STP, KPDES No: KY0103900
Discharge Monitoring Report for July 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Pro Logics STP, for the month July 2022.

There were no overflows or bypasses.

There was two Exceedances for the Month of July due to a faulty blower. The Nitrogen Ammonia Monthly Average limit of 3.0 mg/l with a result of 3.2 mg/l and the Nitrogen Ammonia Daily Maximum limit of 4.5 mg/l with a result of 9.1 mg/l.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith
Process Supervisor

JSS/ PRO LOG 07/22.

Cc: V. Teague/B.Tinnell

