



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

November 11th, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Pro Logics STP, KPDES No: KY0103900
Discharge Monitoring Report for October 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Pro Logics STP, for the month October 2022.

There were no overflows or bypasses

There was one exceedance for the Month of October, Total Suspended Solids percent removal limit of 85.0% with a result of 82.0%. This is a result of low flow at the plant and a low INF TSS.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith
Process Supervisor

JSS/ PRO LOG 10/22.

Cc: V. Teague/B.Tinnell

