

700 West Liberty Street | Louisville, KY 40203-1911 Phone: 502.540.6000 | LouisvilleMSD.org

January 27, 2023

Crystal Dennis
Permit Support Section
Surface Water Permits Branch
Division of Water
200 Fair Oaks Lane, 4th floor
Frankfort, KY 40601

Subject: Top Flight Landing

KPDES Permit No. KY0105074

Dear Ms. Dennis:

Louisville Metropolitan Sewer District (MSD) has entered into a short term contract to provide operation and maintenance services for the Top Flight treatment plant, collection system and pump station. Steve Emily with OHM advisors is our contact for the duration of this contract and will communicate with the owner of the treatment plant and collection system as needed.

In accordance with the provisions of the KPDES permit referenced above, the monthly discharge monitoring report (DMR) for the reporting period of December 1st through December 31st, 2022 are provided and submitted through KY's Net DMR. For the month of December Top Flight failed to meet the monthly average and maximum weekly average for total suspended solids. Total suspended solids had a monthly average result of 41 mg/l and a maximum weekly average result of 66.0 mg/l. This was suspected to be due to a shock load of some kind.

Should you have any additional questions, please contact me at (502) 540-6952.

Sincerely,

William Ford

Process Supervisor-Operations

WEF / TopFlight / 1222

cc:

B. Tinnell

RecordsRequest@louisvillemsd.org

S. Emily, OMH Advisors

DMR Copy of Record

Permit

KY0105074 Permit #:

No Major:

Permittee: Top Flight Landing Permittee Address:

8105 Parkshire Court Louisville, KY 40220

Facility Location:

Facility:

TOP FLIGHT LANDING

HWY 55 S TAYLORSVILLE, KY 40071

Permitted Feature: 001

External Outfall

Discharge: 001-1

Domestic Wastewater

Report Dates & Status

From 12/01/22 to 12/31/22 **Monitoring Period:**

DMR Due Date: 01/28/23

Title:

Status: **NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name: William

Ford

Process Supervisor-Operations

Telephone:

502-540-6000

No Data Indicator (NODI)

Last Name:

Form NODI:

	Parameter Monitoring Location Season # Param. NODI				Quantity or Loading				Quality or Concentration						# of Ex. Frequency of Analysis	Sample Typ			
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier	2 Value 2	Qualifier 3	3 Value 3	Units		
00300	Oxygen, dissolved [DO]	1 - Effluent Gross			Sample						=	8.1					19 - mg/L	01/30 - Monthly	GR - GRAB
			0		Permit Req.						>=	7.0 INST MIN					19 - mg/L	01/30 - Monthly	GR - GRAB
					Value NODI														
00400 p	рН	1 - Effluent Gross	6 0		Sample						=	7.3			=	7.3	12 - SU	01/30 - Monthly	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM	1		<=	9.0 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB
					Value NODI	ı													
					Sample								=	41.0	=	66.0	19 - mg/L	03/30 - Three Per Month	CP - COMPO
X 00530	Solids, total suspended	1 - Effluent Gross	0		Permit Req.								<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L	01/30 - Monthly	CP - COMPC
00330					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross			Sample								=	0.2	=	0.2	19 - mg/L	01/30 - Monthly	CP - COMPC
			2		Permit Req.								<=	10.0 MO AVG	<=	15.0 DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPC
					Value NODI	ı													
00665 Pho	Phosphorus, total [as P]	1 - Effluent Gross			Sample								=	8.73	=	8.73	19 - mg/L	01/30 - Monthly	CP - COMPC
			0		Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPO
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0		Sample	= ().025	= 0).42	03 - MGD								01/30 - Monthly	IN - INSTAN
					Permit Req.	. F	Req Mon MO AVG	e F	Req Mon DAILY M	X 03 - MGD	1							01/30 - Monthly	IN - INSTAN
	·				Value NODI	ı													
51040	E. coli	1 - Effluent Gross	0		Sample								=	21.0		21.0	13 - #/100mL	,	GR - GRAB
					Permit Req.								<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL	01/30 - Monthly	GR - GRAB
					Value NODI														
	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	s 0		Sample								=	9.0	=	9.0	19 - mg/L	01/30 - Monthly	CP - COMPO
80082					Permit Req.								<=	20.0 MO AVG	<=	30.0 MX WK AV	19 - mg/L	01/30 - Monthly	CP - COMPO
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

	Parameter	Manitaring Location	Field		Description	Acknowledge
Code	Name	Monitoring Location			Description Description	
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments

Attachments

Name	Туре	Size
TopFLightCoverletter122022.pdf	pdf	47468.0

Report Last Saved By

Top Flight Landing

User: WILLIAM.FORD@LOUISVILLEMSD.ORG

Name: William Ford

E-Mail: william.ford@louisvillemsd.org

Date/Time: 2023-01-27 11:29 (Time Zone: -05:00)

Report Last Signed By

User: WILLIAM.FORD@LOUISVILLEMSD.ORG

Name: William Ford

E-Mail: william.ford@louisvillemsd.org

Date/Time: 2023-01-27 11:29 (Time Zone: -05:00)