



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

December 20, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: ASH AVE STP, KPDES No: KY0024724
Discharge Monitoring Report for November 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the ASH AVE STP, for the month November 2022.

There were no overflows, bypasses.

There were four exceedances,
TSS monthly average limit 30.0 mg/L with a result of 53.0 mg/L.
TSS maximum weekly average 45.0 mg/L with a result of 92.0 mg/L.
BOD monthly average limit 10.0 mg/L with a result of 11.0 mg/L
BOD maximum weekly average limit of 15.0 mg/L with a result of 16.0 mg/L.

If you have any questions concerning the attached DMR's, please contact me at (502)540-2004.

Sincerely,

Curt Otto
Process Supervisor

CEO/ AA 11/22.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

Permit					
Permit #:	KY0024724	Permittee:	Louisville and Jefferson County MSD	Facility:	ASH AVENUE WWTP
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203	Facility Location:	KY 362 CRESTWOOD, KY 40014
Permitted Feature:	001 External Outfall	Discharge:	001-1 SANITARY WASTEWATER		

Report Dates & Status					
Monitoring Period:	From 11/01/22 to 11/30/22	DMR Due Date:	12/28/22	Status:	NetDMR Validated

Considerations for Form Completion					
Principal Executive Officer					
First Name:	James	Title:	Executive Director	Telephone:	502-540-6000
Last Name:	Parrot				

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.45					19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.					>=	7.0 INST MIN						19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.08			=	7.4	12 - SU	01/07 - Weekly	GR - GRAB
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU	01/07 - Weekly	GR - GRAB	
					Value NODI														
X 00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	52.0			=	92.0	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.					<=	30.0 MO AVG			<=	45.0 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Value NODI														
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	40.28			=	44.0	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.														
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample						=	3.68			=	4.8	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.					<=	7.0 MO AVG			<=	10.5 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	6.96			=	7.82	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.														
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.099	=	0.13	03 - MGD								01/07 - Weekly	IN - INSTAN
					Permit Req.														
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01			<	0.01	19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.						<=	0.011 MO AVG			<=	0.019 DAILY MX	19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	11.0			=	4.0	13 - #/100mL	01/07 - Weekly	GR - GRAB
					Permit Req.						<=	130.0 30DA GEO			<=	240.0 7 DA GEO	13 - #/100mL	01/07 - Weekly	GR - GRAB
					Value NODI														
X 80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample						=	11.0			=	16.0	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Permit Req.						<=	10.0 MO AVG			<=	15.0 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors						
Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments

Attachments

Name	Type	Size
AshCover1122.pdf	pdf	38469.0

Report Last Saved By

Louisville and Jefferson County MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemmsd.org
 Date/Time: 2022-12-21 10:57 (Time Zone: -05:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemmsd.org
 Date/Time: 2022-12-21 11:05 (Time Zone: -05:00)