

**DMR Copy of Record**

<b>Permit</b>					
Permit #:	KY0060577	Permittee:	Louisville and Jefferson County MSD	Facility:	COUNTRY VILLAGE WWTP
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203	Facility Location:	4619 TIMOTHY WAY CRESTWOOD, KY 40014
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater		

<b>Report Dates &amp; Status</b>					
Monitoring Period:	From 05/01/22 to 05/31/22	DMR Due Date:	06/28/22	Status:	NetDMR Validated

**Considerations for Form Completion**

<b>Principal Executive Officer</b>					
First Name:	James	Title:	Executive Director	Telephone:	502-540-6000
Last Name:	Parrot				

**No Data Indicator (NODI)**  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.5					19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.					>=	7.0 INST MIN					19 - mg/L	01/30 - Monthly		GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.65			=	7.65	12 - SU	0	01/30 - Monthly	GR - GRAB
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU	01/30 - Monthly		GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								<	6.0	<	6.0	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.						<=	30.0 MO AVG		<=	45.0 MX WK AV	19 - mg/L	01/30 - Monthly		CP - COMPOS	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	11.4	=	11.4	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.							Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	01/30 - Monthly	GR - GRAB			
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample								=	2.4	=	2.4	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Permit Req.						<=	4.0 MO AVG		<=	6.0 DAILY MX	19 - mg/L	01/30 - Monthly		CP - COMPOS	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	3.3	=	3.3	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.							Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	01/30 - Monthly	GR - GRAB			
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.045	=	0.084	03 - MGD								0	01/30 - Monthly	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							01/30 - Monthly		RC - Recorder (auto)	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								<	0.01	<	0.01	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.							<=	0.011 MO AVG		<=	0.019 DAILY MX	19 - mg/L		01/30 - Monthly	GR - GRAB
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	23.0	=	23.0	13 - #/100mL	0	01/30 - Monthly	GR - GRAB
					Permit Req.							<=	130.0 30DA GEO		<=	240.0 7 DA GEO	13 - #/100mL		01/30 - Monthly	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample								=	5.0	=	5.0	19 - mg/L	0	MEASD - Measured	CP - COMPOS
					Permit Req.							<=	25.0 MO AVG		<=	37.5 MX WK AV	19 - mg/L		MEASD - Measured	CP - COMPOS
					Value NODI															

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

**Attachments**  
No attachments.

**Report Last Saved By**

**Louisville and Jefferson County MSD**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
Name: Curt Otto  
E-Mail: curt.otto@louisvillemmsd.org  
Date/Time: 2022-06-16 11:58 (Time Zone: -04:00)

**Report Last Signed By**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
Name: Curt Otto  
E-Mail: curt.otto@louisvillemmsd.org  
Date/Time: 2022-06-17 14:07 (Time Zone: -04:00)