



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

July 20, 2022

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Country Village STP, KPDES No: KY0060577  
Discharge Monitoring Report for June 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Country Village STP, for the month June 2022.

There were no overflows or bypasses.

There were Five exceedances, TSS monthly average limit of 30 mg/L with a result of 58 mg/L, a maximum weekly average limit of 45 with a result of 58 mg/L. NH3 monthly average limit 4 mg/L with a result of 12.3 mg/L, a daily maximum limit of 6 mg/L with a result of 12.3 mg/L. E Coli 30 day geometric limit of 130 #/100mL with a result of 154.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6004.

Sincerely,

Curt Otto  
Process Supervisor

CEO/ AA 06/22.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

Permit

Permit #:  
Major:

KY0060577  
No

Permittee:  
Permittee Address:

Louisville and Jefferson County MSD  
700 W Liberty St  
Louisville, KY 40203

Facility:  
Facility Location:

COUNTRY VILLAGE WWTP  
4619 TIMOTHY WAY  
CRESTWOOD, KY 40014

Permitted Feature:

001  
External Outfall

Discharge:

001-1  
Domestic Wastewater

Report Dates & Status

Monitoring Period:

From 06/01/22 to 06/30/22

DMR Due Date:

07/28/22

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:  
Last Name:

James  
Parrot

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.5					19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.						>=	7.0 INST MIN					19 - mg/L		01/30 - Monthly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.46			=	7.46	12 - SU	0	01/30 - Monthly	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
					Value NODI															
X00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								=	58.0	=	58.0	19 - mg/L	2	01/30 - Monthly	CP - COMPOS
					Permit Req.								<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	19.0	=	19.0	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/30 - Monthly	GR - GRAB
					Value NODI															
X00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample								=	12.3	=	12.3	19 - mg/L	2	01/30 - Monthly	CP - COMPOS
					Permit Req.								<=	4.0 MO AVG	<=	6.0 DAILY MX	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	4.1	=	4.1	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/30 - Monthly	GR - GRAB
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.035	=	0.077	03 - MGD								0	01/30 - Monthly	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									01/30 - Monthly	RC - Recorder (auto)
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								<	0.01	<	0.01	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.								<=	0.011 MO AVG	<=	0.019 DAILY MX	19 - mg/L		01/30 - Monthly	GR - GRAB
					Value NODI															
X51040	E. coli	1 - Effluent Gross	0	--	Sample								=	154.0	=	154.0	13 - #/100mL	1	01/30 - Monthly	GR - GRAB
					Permit Req.								<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL		01/30 - Monthly	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample								=	12.0	=	12.0	19 - mg/L	0	MEASD - Measured	CP - COMPOS
					Permit Req.								<=	25.0 MO AVG	<=	37.5 MX WK AV	19 - mg/L		MEASD - Measured	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes

Comments

Attachments

Name	Type	Size
Countryvillagecover.pdf	pdf	39831.0

Report Last Saved By

Louisville and Jefferson County MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG

Name: Curt Otto

E-Mail: curt.otto@louisvillemSD.org

Date/Time: 2022-07-20 12:44 (Time Zone: -04:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG

Name: Curt Otto

E-Mail: curt.otto@louisvillemSD.org

Date/Time: 2022-07-20 12:45 (Time Zone: -04:00)