



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

August 17, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Country Village STP, KPDES No: KY0060577
Discharge Monitoring Report for July 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Country Village STP, for the month July 2022.

There were no overflows, exceedances or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Curt Otto
Process Supervisor

CEO/ AA 07/22.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

Permit					
Permit #:	KY0060577	Permittee:	Louisville and Jefferson County MSD	Facility:	COUNTRY VILLAGE WWTP
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203	Facility Location:	4619 TIMOTHY WAY CRESTWOOD, KY 40014
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater		

Report Dates & Status					
Monitoring Period:	From 07/01/22 to 07/31/22	DMR Due Date:	08/28/22	Status:	NetDMR Validated

Considerations for Form Completion

Principal Executive Officer					
First Name:	James	Title:	Executive Director	Telephone:	502-540-6000
Last Name:	Parrot				

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type											
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units									
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.8					19 - mg/L	0	01/30 - Monthly	GR - GRAB								
					Permit Req.					>=	7.0 INST MIN					19 - mg/L	01/30 - Monthly		GR - GRAB									
					Value NODI																							
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.9			=	6.9	12 - SU	0	01/30 - Monthly	GR - GRAB								
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU	01/30 - Monthly		GR - GRAB									
					Value NODI																							
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	7.0		=	7.0	19 - mg/L	0	01/30 - Monthly	CP - COMPOS									
					Permit Req.					<=	30.0 MO AVG		<=	45.0 MX WK AV	19 - mg/L	01/30 - Monthly		CP - COMPOS										
					Value NODI																							
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	21.7		=	21.7	19 - mg/L	0	01/30 - Monthly	GR - GRAB									
					Permit Req.											Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	01/30 - Monthly	GR - GRAB							
					Value NODI																							
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample						=	0.2		=	0.2	19 - mg/L	0	01/30 - Monthly	CP - COMPOS									
					Permit Req.					<=	4.0 MO AVG		<=	6.0 DAILY MX	19 - mg/L	01/30 - Monthly		CP - COMPOS										
					Value NODI																							
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	3.6		=	3.6	19 - mg/L	0	01/30 - Monthly	GR - GRAB									
					Permit Req.													Req Mon MO AVG	Req Mon MX WK AV	19 - mg/L	01/30 - Monthly	GR - GRAB						
					Value NODI																							
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.053	=	0.17	03 - MGD								0	01/30 - Monthly	RC - Recorder (auto)								
					Permit Req.															Req Mon MO AVG	Req Mon DAILY MX	03 - MGD	01/30 - Monthly	RC - Recorder (auto)				
					Value NODI																							
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01		<	0.01	19 - mg/L	0	01/30 - Monthly	GR - GRAB									
					Permit Req.																<=	0.011 MO AVG	<=	0.019 DAILY MX	19 - mg/L	01/30 - Monthly	GR - GRAB	
					Value NODI																							
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	39.0		=	39.0	13 - #/100mL	0	01/30 - Monthly	GR - GRAB									
					Permit Req.																	<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL	01/30 - Monthly	GR - GRAB
					Value NODI																							
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample						=	10.0		=	10.0	19 - mg/L	0	MEASD - Measured	CP - COMPOS									
					Permit Req.																	<=	25.0 MO AVG	<=	37.5 MX WK AV	19 - mg/L	MEASD - Measured	CP - COMPOS
					Value NODI																							

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size

Country0722.pdf

pdf

31445.0

Report Last Saved By

Louisville and Jefferson County MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemsd.org
Date/Time: 2022-08-22 09:58 (Time Zone: -04:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemsd.org
Date/Time: 2022-08-22 10:02 (Time Zone: -04:00)