



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

November 16, 2022

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Country Village STP, KPDES No: KY0060577  
Discharge Monitoring Report for October 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Country Village STP, for the month October 2022.

There were no overflows, exceedances or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)640-6004.

Sincerely,

Curt Otto  
Process Supervisor

CEO/ AA 10/22.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

<b>Permit</b>			
Permit #:	KY0060577	Permittee:	Louisville and Jefferson County MSD
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
		Facility:	COUNTRY VILLAGE WWTP
		Facility Location:	4619 TIMOTHY WAY CRESTWOOD, KY 40014

<b>Report Dates &amp; Status</b>			
Monitoring Period:	From 10/01/22 to 10/31/22	DMR Due Date:	11/28/22
		Status:	NetDMR Validated

Considerations for Form Completion

<b>Principal Executive Officer</b>			
First Name:	James	Title:	Executive Director
Last Name:	Parrot	Telephone:	502-540-6000

No Data Indicator (NODI)  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type							
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units					
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	8.3					19 - mg/L	0	01/30 - Monthly	GR - GRAB				
					Permit Req.						>=	7.0 INST MIN					19 - mg/L		01/30 - Monthly	GR - GRAB				
					Value NODI																			
00400	pH	1 - Effluent Gross	0	--	Sample						=	8.0			=	8.0	12 - SU	0	01/30 - Monthly	GR - GRAB				
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB				
					Value NODI																			
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								<	6.0	<	6.0	19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.							<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L	01/30 - Monthly		CP - COMPOS					
					Value NODI																			
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	26.3			=	26.3	19 - mg/L	0	01/30 - Monthly	GR - GRAB				
					Permit Req.														19 - mg/L	01/30 - Monthly	GR - GRAB			
					Value NODI																			
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample								<	0.2	<	0.2	19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.							<=	4.0 MO AVG	<=	6.0 DAILY MX	19 - mg/L	01/30 - Monthly		CP - COMPOS					
					Value NODI																			
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	3.8			=	3.8	19 - mg/L	0	01/30 - Monthly	GR - GRAB				
					Permit Req.															19 - mg/L	01/30 - Monthly	GR - GRAB		
					Value NODI																			
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.036	=	0.045	03 - MGD								0	01/30 - Monthly	RC - Recorder (auto)				
					Permit Req.																01/30 - Monthly	RC - Recorder (auto)		
					Value NODI																			
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								<	0.01	<	0.01	19 - mg/L	0	01/30 - Monthly	GR - GRAB				
					Permit Req.																	19 - mg/L	01/30 - Monthly	GR - GRAB
					Value NODI																			
51040	E. coli	1 - Effluent Gross	0	--	Sample								<	1.0	<	1.0	13 - #/100mL	0	01/30 - Monthly	GR - GRAB				
					Permit Req.																	13 - #/100mL	01/30 - Monthly	GR - GRAB
					Value NODI																			
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample						=	6.0			=	6.0	19 - mg/L	0	MEASD - Measured	CP - COMPOS				
					Permit Req.																	19 - mg/L	MEASD - Measured	CP - COMPOS
					Value NODI																			

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

<b>Attachments</b>		
Name	Type	Size

**Report Last Saved By**

**Louisville and Jefferson County MSD**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
Name: Curt Otto  
E-Mail: curt.otto@louisvillemsd.org  
Date/Time: 2022-11-16 10:36 (Time Zone: -05:00)

**Report Last Signed By**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
Name: Curt Otto  
E-Mail: curt.otto@louisvillemsd.org  
Date/Time: 2022-11-16 11:10 (Time Zone: -05:00)