



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

July 25, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Lockwood STP, KPDES No: KY0054674
Discharge Monitoring Report for June 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Lockwood STP, for the month June 2022.

There were no overflows, exceedances or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Curt Otto
Process Supervisor

CEO/ AA 06/22.

Cc: V. Teague, B. Tinnel



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

July 25, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: SORF STP, KPDES No: KY0111716
Discharge Monitoring Report for June 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the SORF STP, for the month June 2022.

There were no overflows or bypasses.

There are Two exceedances, Phosphorus Monthly average limit of 1.0 with a result of 2.7 and a Daily Maximum of 2 with a result of 3.5.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6004.

Sincerely,

Curt Otto
Process Supervisor

CEO/ AA 06/22.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

Permit			
Permit #:	KY0054674	Permittee:	Louisville and Jefferson County MSD
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
Facility:	LOCKWOOD ESTATES SUBDIVISION WWTP		
Facility Location:	3718 BARBARA ANN BLVD CRESTWOOD, KY 40014		

Report Dates & Status			
Monitoring Period:	From 06/01/22 to 06/30/22	DMR Due Date:	07/28/22
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	James	Title:	Executive Director
Last Name:	Parrot	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type						
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units				
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	7.5					19 - mg/L	0	01/30 - Monthly	GR - GRAB				
					Permit Req.					>=	7.0 MINIMUM					19 - mg/L		01/30 - Monthly	GR - GRAB				
					Value NODI																		
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.68			=	7.68	12 - SU	0	01/30 - Monthly	GR - GRAB				
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB				
					Value NODI																		
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample							<	6.0	<	6.0	19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.						<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L	01/30 - Monthly		CP - COMPOS					
					Value NODI																		
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample					=	16.6			=	16.6	19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.											Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS		
					Value NODI																		
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	0.013	=	0.013	26 - lb/d		=	0.3	=	0.3	19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.	<=	1.5 MO AVG	<=	2.25 MX WK AV	26 - lb/d		<=	4.0 MO AVG	<=	6.0 DAILY MX	19 - mg/L		01/30 - Monthly	CP - COMPOS				
					Value NODI																		
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	1.63			=	1.63	19 - mg/L	0	01/30 - Monthly	CP - COMPOS			
					Permit Req.														Req Mon MO AVG	Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS
					Value NODI																		
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.005	=	0.011	03 - MGD							0	01/30 - Monthly	IN - INSTAN				
					Permit Req.														Req Mon MO AVG	Req Mon DAILY MX	03 - MGD	01/30 - Monthly	IN - INSTAN
					Value NODI																		
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample							<	0.01	<	0.01	19 - mg/L	0	01/30 - Monthly	GR - GRAB				
					Permit Req.											<=		0.011 MO AVG	<=	0.019 DAILY MX	19 - mg/L	01/30 - Monthly	GR - GRAB
					Value NODI																		
51040	E. coli	1 - Effluent Gross	0	--	Sample							=	11.0	=	11.0	13 - #/100mL	0	01/30 - Monthly	GR - GRAB				
					Permit Req.											<=		130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL	01/30 - Monthly	GR - GRAB
					Value NODI																		
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	0.167	=	0.167	26 - lb/d		<	4.0	<	4.0	19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.	<=	9.38 MO AVG	<=	14.07 MX WK AV	26 - lb/d		<=	25.0 MO AVG	<=	37.5 MX WK AV	19 - mg/L		01/30 - Monthly	CP - COMPOS				
					Value NODI																		

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size

Report Last Saved By

Louisville and Jefferson County MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemmsd.org
Date/Time: 2022-07-25 08:01 (Time Zone: -04:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemmsd.org
Date/Time: 2022-07-25 08:01 (Time Zone: -04:00)