



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

September 26, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Ohio River STP, KPDES No: KY0106143
Discharge Monitoring Report for August 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Ohio River STP, for the month August 2022.

There were no overflows, exceedances or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Curt Otto
Process Supervisor

CEO/ AA 08/22.

Cc: V. Teague, B. Tinnel

51040	E. coli	1 - Effluent Gross	0	--	Sample	=	92.0	=	112.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB
					Permit Req.	<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL		01/07 - Weekly	GR - GRAB
					Value NODI								
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=	96.0			23 - %	0	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN			23 - %		01/30 - Monthly	CA - CALCTD
					Value NODI								
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	96.0			23 - %	0	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN			23 - %		01/30 - Monthly	CA - CALCTD
					Value NODI								

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
OhioRiverCoverletter.pdf	pdf	31278.0

Report Last Saved By

Louisville and Jefferson County MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemsd.org
Date/Time: 2022-09-26 10:41 (Time Zone: -04:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemsd.org
Date/Time: 2022-09-26 10:42 (Time Zone: -04:00)