



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

January 23, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Ohio River STP, KPDES No: KY0106143
Discharge Monitoring Report for December 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Ohio River STP, for the month December 2022.

Also attached is 4th quarter biomonitoring and 2-4 year sampling.

There were no overflows or bypasses.

There was one exceedance E Coli 30 geomean limit 130 #100/mL, result of 483 #100/mL.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Curt Otto
Process Supervisor

CEO/ AA 12/22.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

Permit																			
Permit #:	KY0106143			Permittee:	Louisville and Jefferson County MSD				Facility:	OHIO RIVER WWTP									
Major:	Yes			Permittee Address:	700 W Liberty St Louisville, KY 40203				Facility Location:	1901 LANDING RD GOSHEN, KY 40026									
Permitted Feature:	001 External Outfall			Discharge:	001-2 Quarterly Biomonitoring														
Report Dates & Status																			
Monitoring Period:	From 10/01/22 to 12/31/22			DMR Due Date:	01/28/23				Status:	NetDMR Validated									
Considerations for Form Completion																			
Principal Executive Officer																			
First Name:	James			Title:	Executive Director				Telephone:	502-540-6000									
Last Name:	Parrot																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Sample Permit Req. Value NODI	Quantity or Loading				Quality or Concentration				# of Ex.	Frequency of Analysis	Sample Type			
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2				Value 2	Qualifier 3	Value 3
61406	Toxicity, final conc toxicity units	1 - Effluent Gross	0	--											<	1.0	2F - tox acute	01/90 - Quarterly	24 - COMP24
															<=	1.0 MAXIMUM	2F - tox acute	01/90 - Quarterly	24 - COMP24
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Attachments																			
No attachments.																			
Report Last Saved By																			
Louisville and Jefferson County MSD																			
User:	CURT.OTTO@LOUISVILLEMSD.ORG																		
Name:	Curt Otto																		
E-Mail:	curt.otto@louisvillemmsd.org																		
Date/Time:	2023-01-23 09:45 (Time Zone: -05:00)																		
Report Last Signed By																			
User:	CURT.OTTO@LOUISVILLEMSD.ORG																		
Name:	Curt Otto																		
E-Mail:	curt.otto@louisvillemmsd.org																		
Date/Time:	2023-01-23 11:41 (Time Zone: -05:00)																		