



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

June 16th, 2022

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: SORF STP, KPDES No: KY0111716
Discharge Monitoring Report for May 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the SORF STP, for the month May 2022.

There were no overflows.

There are Three exceedances, Phosphorus Monthly average limit of 1.0 with a result of 1.1 and a Daily Maximum of 2 with a result of 2.4. E Coli 7-day Geometric limit of 240 with a result of 285.0

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Curt Otto
Process Supervisor

CEO/ AA 05/22.

Cc: V. Teague, B. Tinnel

