



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

May 21, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Cedar Creek WQTC, KPDES No: KY0098540
Discharge Monitoring Report for April 2023.**

Dear Mrs. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Cedar Creek WQTC, for the month of April 2023.

There were no exceedances, bypasses, or discharges to report.

If you have any questions concerning the attached DMR's, please contact me at (502) 540-6952.

Sincerely,

A handwritten signature in blue ink, appearing to read 'W. Ford', is written over the printed name and title of the sender.

William E. Ford
Process Supervisor-Operations

WEF/ Cedar Creek. 05/23.

Enclosures

Cc: V. Graves
B. Tinnel

DMR Copy of Record

Permit

Permit #:

KY0098540

Major:

Yes

Permittee:

Cedar Creek WQTC MSD

Permittee Address:

700 W Liberty St
Louisville, KY 40203

Facility:

CEDAR CREEK WQTC MSD

Facility Location:

8405 CEDAR CREEK RD
LOUISVILLE, KY 40291

Permitted Feature:

001
External Outfall

Discharge:

001-1
MUNICIPAL DISCHARGE

Report Dates & Status

Monitoring Period:

From 04/01/23 to 04/30/23

DMR Due Date:

05/28/23

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

James A.

Last Name:

Parrott

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	8.0					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.0			=	8.3	12 - SU	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/07 - Weekly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	119.0	=	152.0	26 - lb/d			=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	1877.0 MO AVG	<=	2815.0 MX WK AV	26 - lb/d			<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample								=	108.0	=	146.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	6.0	=	6.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample	=	13.0	=	23.0	26 - lb/d			=	0.4	=	0.7	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	626.0 MO AVG	<=	939.0 MX WK AV	26 - lb/d			<=	10.0 MO AVG	<=	15.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	2	--	Sample								=	0.3	=	0.3	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.								<=	2.0 MO AVG	<=	3.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	4.561	=	5.69	03 - MGD								0	99/99 - Continuous	CN - CONTIN
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD									99/99 - Continuous	RE - Record (manual)
					Value NODI															
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	6.245	=	7.057	03 - MGD								0	99/99 - Continuous	CN - CONTIN
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD									99/99 - Continuous	RE - Record (manual)
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	1.0	=	2.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB
					Permit Req.								<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL		01/07 - Weekly	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	109.0	=	152.0	26 - lb/d			=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	626.0 MO AVG	<=	939.0 MX WK AV	26 - lb/d			<=	10.0 MO AVG	<=	15.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample								=	126.0	=	167.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24
					Value NODI															
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample						=	98.0					23 - %	0	01/30 - Monthly	CA - CALCTD
					Permit Req.						>=	85.0 MO AV MN					23 - %		01/30 - Monthly	CA - CALCTD
					Value NODI															

81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample						=	97.0					23 - %	0	01/30 - Monthly	CA - CALCTD
					Permit Req.						>=	85.0 MO AV MN					23 - %		01/30 - Monthly	CA - CALCTD
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
CCCoverletter042023.pdf	pdf	34499.0
CCMOR042023.pdf	pdf	131503.0

Report Last Saved By

Cedar Creek WQTC MSD

User: staci.huber@louisvillemSD.org

Name: Staci Huber

E-Mail: staci.huber@louisvillemSD.org

Date/Time: 2023-05-24 11:03 (Time Zone: -04:00)

Report Last Signed By

User: WILLIAM.FORD@LOUISVILLEMSD.ORG

Name: William Ford

E-Mail: william.ford@louisvillemSD.org

Date/Time: 2023-05-24 14:23 (Time Zone: -04:00)

2023

CEDAR CREEK

$$\text{SEWER CONNECTIONS} \quad 0 \quad \times \quad 4 \quad = \quad 0 \quad \text{SEWERED POPULATION}$$

PLANT TELEPHONE