



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

February 27, 2023

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784  
Discharge Monitoring Report for January 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Floyds Fork Water Quality Treatment Center for the month of January 2023.

There were no bypasses or exceedances. Additionally, the monthly Overflow Report is attached.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6952.

Sincerely,

William Ford  
Process Supervisor-Operations

WEF/ Floyds Fork 01/23

Cc: V. Teague  
B. Tinnell



81011	<b>Solids, suspended percent removal</b>	K - Percent Removal	0	--	Sample	=	98.0										23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.	>=	85.0 MO AV MN										23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI															

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
FFCoverletter012023.pdf	pdf	33485.0
FFMOR012023.pdf	pdf	145740.0
FFOverflowReport012023.pdf	pdf	190060.0

**Report Last Saved By**

**Floyds Fork WQTC MSD**

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG  
 Name: Joseph Smith  
 E-Mail: joseph.smith@louisvillemmsd.org  
 Date/Time: 2023-02-28 13:04 (Time Zone: -05:00)

**Report Last Signed By**

User: WILLIAM.FORD@LOUISVILLEMSD.ORG  
 Name: William Ford  
 E-Mail: william.ford@louisvillemmsd.org  
 Date/Time: 2023-02-28 13:25 (Time Zone: -05:00)





**IMSAST0004  
Overflow Report**

**1/1/2023 12:00:00 AM to 1/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Main	107136B-V	13820 OLD HENRY RD	FLOYDS FORK	FLOYDS FORK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3609578		1/30/2023 1:10:00 PM	ROTTET JR	ROTTET JR	REPAIRED - ISSUE RESOLVED	1/20/2023 12:00:00 AM	UTILITY DAMAGED MSD ASSET	UNAUTHORIZED DISCHARGE- WATERS	01/30/23 02:15 PM	

**Discharge Reporting:**

Discharge Amount:	325 GAL
Cause:	CONTRACTOR DAMAGED FORCE MAIN.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	TEMPORARY SIGNS INSTALLED AROUND IMPACTED AREA.
Impact:	SEWAGE AND DEBRIS AROUND IMPACTED AREA.
Repair:	HAULED STATION WHILE REPAIRS MADE.
Public Notification:	TEMPORARY SIGNS INSTALLED AROUND IMPACTED AREA.

**Notifications:**

1/31/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--



**IMSAST0004  
Overflow Report  
1/1/2023 12:00:00 AM to 1/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	NA

  

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	33003	815 TUCKER STATION RD	FLOYDS FORK	POPE LICK	STREAM

  

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3600648		1/3/2023 12:10:00 PM	FRENCH		BEYOND APPROVED DESIGN STORM	1/3/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	01/03/23 02:10 PM	

**Discharge Reporting:**

Discharge Amount:	1,200 GAL
Cause:	LACK OF CAPACITY.
Clean Up:	MSD PERSONNEL WILL CLEAN AND SANITIZE THE IMPACTED AREA.
Control Zone:	PERMANENT OVERFLOW WARNING SIGNS POSTED.
Impact:	SOLIDS AND DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN THE IOAP.
Public Notification:	PUBLIC NOTIFIED WITH SIGNS.

**Notifications:**

1/4/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
1/4/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	NA

  

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	65516	12400 BRIERLY HILL PL	FLOYDS FORK	POPE LICK	GROUND

  

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3600649		1/3/2023 12:00:00 PM	FRENCH		BEYOND APPROVED DESIGN STORM	1/3/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	01/03/23 02:00 PM	

**Discharge Reporting:**

Discharge Amount:	1,200 GAL
Cause:	LACK OF CAPACITY.
Clean Up:	MSD PERSONNEL WILL CLEAN AND SANITIZE THE IMPACTED AREA.
Control Zone:	PERMANENT OVERFLOW WARNING SIGNS POSTED.
Impact:	SOLIDS AND DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN THE IOAP.
Public Notification:	PUBLIC NOTIFIED WITH SIGNS.

**Notifications:**

1/4/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
----------------	--------	---



**IMSAST0004**  
**Overflow Report**  
**1/1/2023 12:00:00 AM to 1/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region							
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	NA							
Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To						
Sewer Main	80369A	600 N BECKLEY STATION RD	FLOYDS FORK	FLOYD FORK	STREAM						
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW:DRY WEATHER DISCHARGE	3602743		1/17/2023 3:19:00 PM	HANNAH		REPAIRED - ISSUE RESOLVED	1/18/2023 12:00:00 AM	ROOTS	UNAUTHORIZED DISCHARGE-WATERS	01/18/23 10:00 AM	LAT

**Discharge Reporting:**

Discharge Amount:	1 GAL
Cause:	ROOTS IN MAIN SEWER.
Clean Up:	MSD CLEANED IMPACTED AREA.
Control Zone:	ADVISED CUSTOMER TO AVOID IMPACTED AREA WITH MSD DISCHARGE SIGNS.
Impact:	SEWAGE/WATER DISCHARGING FROM MANHOLE INTO LAKE.
Repair:	FLUSHED/VACTORED THE GREASE FROM THE SEWER IN THE RESIDENTIAL AREA.
Public Notification:	ON SITE.

**Notifications:**

1/18/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
1/18/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION