



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

May 21, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for April 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Floyds Fork Water Quality Treatment Center for the month of April 2023.

There were no bypasses, discharges, or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6952.

Sincerely,

William Ford
Process Supervisor-Operations

WEF/ Floyds Fork 05/23

Cc: V. Teague
B. Tinnel

81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	99.0										23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.	>=	85.0 MO AV MN										23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
FFCoverletter042023.pdf	pdf	33119.0
FFMOR042023.pdf	pdf	184582.0

Report Last Saved By

Floyds Fork WQTC MSD

User: staci.huber@louisvillemsd.org
 Name: Staci Huber
 E-Mail: staci.huber@louisvillemsd.org
 Date/Time: 2023-05-24 11:08 (Time Zone: -04:00)

Report Last Signed By

User: WILLIAM.FORD@LOUISVILLEMSD.ORG
 Name: William Ford
 E-Mail: william.ford@louisvillemsd.org
 Date/Time: 2023-05-24 14:24 (Time Zone: -04:00)

NAME OF TREATMENT PLANT Floyds Fork

COUNTY Jefferson

Month of: April 2023

Avg. Flow: 4.24

Date	Rainfall	Sludge Disposal	
		in Gallons	Remarks
1	0	80000	
2	0	80000	
3	0	80000	
4	0	60000	
5	0.37	100000	
6	0	100000	
7	0	80000	
8	0	80000	
9	0	80000	
10	0	60000	
11	0	60000	
12	0	80000	
13	0	80000	
14	0	80000	
15	0	60000	
16	0	60000	
17	0	60000	
18	0	60000	
19	0	60000	
20	0	60000	
21	0.4	80000	
22	0.09	80000	
23	0	80000	
24	0	80000	
25	0	60000	
26	0	80000	
27	0.75	80000	
28	0.13	80000	
29	0.01	80000	
30	0	80000	
31		0	