



700 West Liberty Street || Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

August 24, 2023

Crystal Dennis  
Permit Support Section  
Surface Water Permits Branch  
Division of Water  
300 Sower Blvd, 3rd Floor  
Frankfort, Kentucky 40601

**RE:   Floyds Fork WQTC, KPDES No: KY0102784  
      Discharge Monitoring Report for July 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Floyds Fork Water Quality Treatment Center for the month of July 2023.

There were no bypasses or exceedances.

The overflow report is attached.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6952.

Sincerely,

William Ford  
Process Supervisor-Operations

WEF/ Floyds Fork 08/23

Cc:   V. Teague  
      B. Tinnel



81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	100.0								23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN							23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI												

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
FFCoverletter072023.pdf	pdf	33154.0
FFMOR072023.pdf	pdf	138680.0
FFOverflowReport072023.pdf	pdf	62238.0

**Report Last Saved By**

**Floyds Fork WQTC MSD**

User: WILLIAM.FORD@LOUISVILLEMSD.ORG  
 Name: William Ford  
 E-Mail: william.ford@louisvillemmsd.org  
 Date/Time: 2023-08-24 09:25 (Time Zone: -04:00)

**Report Last Signed By**

User: WILLIAM.FORD@LOUISVILLEMSD.ORG  
 Name: William Ford  
 E-Mail: william.ford@louisvillemmsd.org  
 Date/Time: 2023-08-25 08:38 (Time Zone: -04:00)





**IMSAST0004  
Overflow Report  
6/1/2023 12:00:00 AM to 6/30/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	NA

  

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Service Line	139375	14510 LANDIS LAKES DR	FLOYDS FORK	FLOYDS FORK	DITCH

  

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW:DRY WEATHER DISCHARGE	3669475		6/22/2023 2:03:00 PM	WEAVER JR	WEAVER JR	REPAIRED - ISSUE RESOLVED	6/22/2023 12:00:00 AM	GREASE BLOCKAGE	UNAUTHORIZED DISCHARGE-WATERS	06/22/23 05:50 PM	MAIN

**Discharge Reporting:**

Discharge Amount:	600 GAL
Cause:	GREASE OBSTRUCTION IN SANITARY MAIN.
Clean Up:	WATER HAS NOT RECEDED - CUSTOMER ADVISED TO CONTACT CUSTOMER RELATIONS WHEN WATER RECEDES.
Control Zone:	ADVISED CUSTOMER TO AVOID CONTACT WITH IMPACTED AREA.
Impact:	SEWAGE/WATER DISCHARGING FROM MANHOLE.
Repair:	NO FURTHER ACTION NEEDED FROM MSD AT THIS TIME.
Public Notification:	ADVISED CUSTOMER ON SITE.

**Notifications:**

6/23/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---