



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

February 21, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Ohio River STP, KPDES No: KY0106143
Discharge Monitoring Report for January 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Ohio River STP, for the month January 2023.

There were no overflows, exceedances or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6004.

Sincerely,

A handwritten signature in black ink, appearing to read 'Curt Otto', written in a cursive style.

Curt Otto
Process Supervisor

CEO/ AA 01/23.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

Permit

Permit #:

KY0106143

Major:

Yes

Permittee:

Louisville and Jefferson County MSD

Permittee Address:

700 W Liberty St
Louisville, KY 40203

Facility:

OHIO RIVER WWTP

Facility Location:

1901 LANDING RD
GOSHEN, KY 40026

Permitted Feature:

001
External Outfall

Discharge:

001-1
Domestic Wastewater from a Publicly Owned Treatment Works

Report Dates & Status

Monitoring Period:

From 01/01/23 to 01/31/23

DMR Due Date:

02/28/23

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

James

Last Name:

Parrot

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

51040	E. coli	1 - Effluent Gross	0	--	Sample								=	21.0	=	14.0	13 - #/100mL	01/07 - Weekly	GR - GRAB
					Permit Req.								<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL	01/07 - Weekly	GR - GRAB
					Value NODI														
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample								=	97.0			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.								>=	85.0 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample								=	90.0			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.								>=	85.0 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Jan23OhioCover.pdf	pdf	31979.0

Report Last Saved By

Louisville and Jefferson County MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG

Name: Curt Otto

E-Mail: curt.otto@louisvillemSD.org

Date/Time: 2023-02-21 12:13 (Time Zone: -05:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG

Name: Curt Otto

E-Mail: curt.otto@louisvillemSD.org

Date/Time: 2023-02-21 12:24 (Time Zone: -05:00)