



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

September 17, 2023

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Pro Logics STP, KPDES No: KY0103900  
Discharge Monitoring Report for August 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Pro Logics STP, for the month August 2023.

There were no overflows, discharges or exceedances.

MSD had two exceedances for the month of August. Effluent total phos. for the second week and for the monthly average. The metering pump wasn't pumping to the desired spec.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Kevin Thompson  
Process Supervisor

JSS/ PRO LOG 08/23.

Cc: V. Teague/B.Tinnell



