



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

January 25, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Pro Logics STP, KPDES No: KY0103900
Discharge Monitoring Report for December 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Pro Logics STP, for the month of December 2023.

There were no exceedances, overflows or discharges.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Jon Baldridge
Process Supervisor

JOB/ PRO LOG 12/23.

Cc: V. Teague/B.Tinnell

80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample	=	337.0	=	521.0	19 - mg/L	01/07 - Weekly	24 - COMP24	
					Permit Req.					19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI								
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample	=	99.0			23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.	>=	85.0 MO AV MN			23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI								
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	98.7			23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.	>=	85.0 MO AV MN			23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI								

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Prologis.pdf	pdf	32145.0

Report Last Saved By

Louisville and Jefferson County MSD

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
 Name: Jonathan Baldrige
 E-Mail: jon.baldrige@louisvillemmsd.org
 Date/Time: 2024-01-25 11:00 (Time Zone: -05:00)

Report Last Signed By

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
 Name: Jonathan Baldrige
 E-Mail: jon.baldrige@louisvillemmsd.org
 Date/Time: 2024-01-25 11:20 (Time Zone: -05:00)