



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

September 24, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Bullitt Hills STP, KPDES No: KY0034801
Discharge Monitoring Report for August 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Bullitt Hills STP, for the month of August 2024.

There were no Bypasses, or overflows to report.

Bullitt Hills had one exceedance for ammonia daily max. Sample result 12.4mg/l permit limit 6mg/l
This was a result of a rain event with lack of capacity resulting in having blowers off to contain solids inside the plant. Blowers were returned to full service.

If you have any questions concerning the attached DMR's, please contact me at (502) 540-6717

Sincerely,

Jon Baldrige
Process Supervisor

JOB/ BH 08/23.

Cc: V. Teague / B. Tinnell

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments**Attachments**

Name	Type	Size
BullittHillscoverletter.pdf	pdf	191169.0

Report Last Saved By**Louisville and Jefferson County MSD**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
 Name: Jonathan Baldrige
 E-Mail: jon.baldrige@louisvillemmsd.org
 Date/Time: 2024-09-24 10:38 (Time Zone: -04:00)

Report Last Signed By

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
 Name: Jonathan Baldrige
 E-Mail: jon.baldrige@louisvillemmsd.org
 Date/Time: 2024-09-24 12:35 (Time Zone: -04:00)