



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

December 3, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Bullitt Hills STP, KPDES No: KY0034801
Discharge Monitoring Report for November 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Bullitt Hills STP, for the month of November 2024.

There were no exceedances, overflows, or bypasses to report.

If you have any questions concerning the attached DMR's, please contact me at (502) 540-6717

Sincerely,

Jon Baldridge
Process Supervisor

JOB/ BH 11/23.

Cc: V. Teague / B. Tinnell

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #:

KY0034801

Major:

No

Permittee:

Louisville and Jefferson County MSD

Permittee Address:

700 W Liberty St
Louisville, KY 40203

Facility:

BCSD BULLITT HILLS SUBDIVISION

Facility Location:

12105 PRESTON HWY
HILLVIEW, KY 40229

Permitted Feature:

001
External Outfall

Discharge:

001-1
Domestic Wastewater

Report Dates & Status

Monitoring Period:

From 11/01/24 to 11/30/24

DMR Due Date:

12/28/24

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

James A.

Last Name:

Parrott

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.1					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	7.0 INST MIN					19 - mg/L			
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.8			=	7.3	12 - SU	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU			
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								=	15.0	=	21.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.								<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L			
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	21.1	=	25.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L			
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample								=	0.6	=	1.7	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.								<=	10.0 MO AVG	<=	15.0 DAILY MX	19 - mg/L			
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	3.75	=	4.79	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L			
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.309	=	1.068	03 - MGD								0	01/07 - Weekly	IN - INSTAN
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD										
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								<	0.01	<	0.01	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.								<=	0.011 MO AVG	<=	0.019 DAILY MX	19 - mg/L			
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	1.0	=	1.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB
					Permit Req.								<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL			
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample								=	8.0	=	9.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.								<=	25.0 MO AVG	<=	37.5 MX WK AV	19 - mg/L			

					Value NODI													
Submission Note																		
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																		
Edit Check Errors																		
No errors.																		
Comments																		
Attachments																		
Name												Type				Size		
BullittHillscoverletter.pdf												pdf				245819.0		
Report Last Saved By																		
Louisville and Jefferson County MSD																		
User:						CURT.OTTO@LOUISVILLEMSD.ORG												
Name:						Curt Otto												
E-Mail:						curt.otto@louisvillemSD.org												
Date/Time:						2024-12-19 08:56 (Time Zone: -05:00)												
Report Last Signed By																		
User:						CURT.OTTO@LOUISVILLEMSD.ORG												
Name:						Curt Otto												
E-Mail:						curt.otto@louisvillemSD.org												
Date/Time:						2024-12-19 08:57 (Time Zone: -05:00)												