

700 West Liberty Street | Louisville, KY 40203-1911 Phone: 502.540.6000 | LouisvilleMSD.org

December 16th, 2024

Crystal Dennis 300 Sower Blvd., 3rd Floor Frankfort, Kentucky 40601

**RE:** Country Village STP, KPDES No: KY0060577

Discharge Monitoring Report for November 2024.

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Country Village STP, for the month November 2024.

There were no overflows or bypasses. We had one exceedance for 7-day weekly Geo for E. Coli with a permit limit of 240 mg/L and a result of 31571 mg/L. We had chemical pump issues that have been rectified. We passed monthly E. Coli for that fact.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely

Alex Smither Process Supervisor

CAS/CV 11/24.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the <a href="https://www.npde.com/npack-need-to-the-number-or non-business email address)">non-business email address)</a>, confidential business information (e.g., non-business cell phone number or non

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(I)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit					
Permit #:	KY0060577	Permittee:	Louisville and Jefferson County MSD	Facility:	COUNTRY VILLAGE WWTP
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203	Facility Location:	4619 TIMOTHY WAY CRESTWOOD, KY 40014
Permitted Feature:	001 External Outfall	Discharge:	<b>001-1</b> Domestic Wastewater		
Report Dates & Status					
Monitoring Period:	From 11/01/24 to 11/30/24	DMR Due Date:	12/28/24	Status:	NetDMR Validated
Considerations for Form Completion					
Principal Executive Officer					
First Name:	Tony	Title:	Executive Director	Telephone:	502-540-6533

No Data Indicator (NODI)

Parrott

**Last Name:** 

Form NOI	DI:																		
	Parameter Monitoring Location Season # Param. NODI			Quantity or Loading			Quality or Concentration							# of Ex. Frequency of Analysis	s Sample Type				
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier	3 Value 3	Units		
					Sample						= 8	3.0					19 - mg/L	01/30 - Monthly	GR - GRAB
00300 <b>Oxyg</b>	Oxygen, dissolved [DO]	1 - Effluent Gross	0		Permit Req.						>=	7.0 INST MI	N				19 - mg/L	01/30 - Monthly	GR - GRAB
					Value NODI														
					Sample						= '	7.6			-	7.6	12 - SU	01/30 - Monthly	GR - GRAB
00400	pH	1 - Effluent Gross	0		Permit Req.						>= (	6.0 MINIMUN	М		<=	9.0 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB
					Value NODI														
		1 - Effluent Gross	0		Sample									6.0	<	6.0	19 - mg/L		CP - COMPOS
00530	Solids, total suspended				Permit Req.								<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L	01/30 - Monthly	CP - COMPOS
	,				Value NODI														
					Sample								=	33.9	=	33.9	19 - mg/L	01/30 - Monthly	GR - GRAB
00600	Nitrogen, total [as N]	1 - Effluent Gross	0		Permit Req.									Req Mon MO AVO	3	Req Mon MX WK AV	19 - mg/L	01/30 - Monthly	GR - GRAB
					Value NODI														
		1 - Effluent Gross	2		Sample								<	0.2	<	0.2	19 - mg/L	01/30 - Monthly	CP - COMPOS
00610	Nitrogen, ammonia total [as N]				Permit Req.								<=	10.0 MO AVG	<=	15.0 DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS
					Value NODI														
					Sample								=	6.16	=	6.16	19 - mg/L	01/30 - Monthly	GR - GRAB
00665	Phosphorus, total [as P]	1 - Effluent Gross	0		Permit Req.									Req Mon MO AVO	}	Req Mon MX WK AV	19 - mg/L	01/30 - Monthly	GR - GRAB
00000	i nospilorus, total [us i ]	1 Emacin Gross			Value NODI														
					Sample	= 0	0.062	=	0.157	03 - MGD								01/30 - Monthly	RC - Recorder (auto)
50050 Flow, in conduit or	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0		Permit Req.	F	Req Mon MO AV	G	Req Mon DAILY MX	03 - MGD								01/30 - Monthly	RC - Recorder (auto)
	,				Value NODI														
					Sample								=	0.01	=	0.01	19 - mg/L	01/30 - Monthly	GR - GRAB
50060 Ch	Chlorine, total residual	1 - Effluent Gross	0		Permit Req.								<=	0.011 MO AVG	<=	0.019 DAILY MX	19 - mg/L	01/30 - Monthly	GR - GRAB
					Value NODI														
					Sample								=	96.0	=	31571.0	13 - #/100mL	01/30 - Monthly	GR - GRAB
<b>X</b> 51040	F coli	1 - Effluent Gross	0		Permit Req.								<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL	01/30 - Monthly	GR - GRAB
<b>∧</b> 51040	2. 3011	Emacin Cioco			Value NODI														
					Sample								=	8.0	=	8.0	19 - mg/L	MEASD - Measured	CP - COMPOS
80082	POD corbanacius IE day 20 Cl	1 - Effluent Gross	0		Permit Req.								<=	25.0 MO AVG	<=	37.5 MX WK AV	19 - mg/L	MEASD - Measured	CP - COMPOS
00002	BOD, carbonaceous [5 day, 20 C]	i - Elliuelii Gioss	U	-															

Value NODI **Submission Note** If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type. **Edit Check Errors** Parameter **Monitoring Location** Field Type Description Acknowledge Code Name 51040 E. coli 1 - Effluent Gross Quality or Concentration Sample Value 3 Soft The provided sample value is outside the permit limit. Please verify that the value you have provided is correct. Yes Comments **Attachments** Name Туре Size C\_VILLAGE\_COVER\_11\_24.pdf pdf 35136.0 Report Last Saved By Louisville and Jefferson County MSD ALEX.SMITHER@LOUISVILLEMSD.ORG User: Name: Charles Smither E-Mail: alex.smither@louisvillemsd.org 2024-12-16 10:18 (Time Zone: -05:00) Date/Time: Report Last Signed By ALEX.SMITHER@LOUISVILLEMSD.ORG User: Name: Charles Smither E-Mail: alex.smither@louisvillemsd.org Date/Time: 2024-12-16 10:19 (Time Zone: -05:00)