



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

February 20, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Pro Logics STP, KPDES No: KY0103900
Discharge Monitoring Report for January 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Pro Logics STP, for the month of January 2024.

There were no overflows or discharges.

There was one exceedance for NH₃ daily maximum, permit limit is 12 mg/L, sample result 13.3 mg/L. This was due to a blower malfunction. Blower has been repaired. We are now in compliance.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6717.

Sincerely,

Jon Baldrige
Process Supervisor

JOB/ PRO LOG 12/23.

Cc: V. Teague/B.Tinnell

