



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

December 22nd, 2025

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Bullitt Hills STP, KPDES No: KY0034801
Discharge Monitoring Report for November 2025.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Bullitt Hills STP, for the month of November 2025.

There were no overflows or bypasses.

There was one exceedance ammonia daily maximum with a result of 17.8ppm and a limit of 15.0ppm

If you have any questions concerning the attached DMR's, please contact me at (502) 919-5794.

Sincerely,

Scott Reed
Process Supervisor

SR/BH 11/25.

Cc: V. Teague, B. Tinnel

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments**Attachments**

Name	Type	Size
BullittHillsCover11_25.pdf	pdf	33432.0

Report Last Saved By**Louisville and Jefferson County MSD**

User: REED0325
 Name: Scott Reed
 E-Mail: reeds@louisvillemd.org
 Date/Time: 2025-12-23 12:49 (Time Zone: -05:00)

Report Last Signed By

User: REED0325
 Name: Scott Reed
 E-Mail: reeds@louisvillemd.org
 Date/Time: 2025-12-26 10:25 (Time Zone: -05:00)