



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

September 15th, 2025

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Hillview 2 STP, KPDES No: KY00034169  
Discharge Monitoring Report for August 2025.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview Plant #2 WQTC, for the month of August 2025.

There were no overflows or bypasses.

There was one exceedance for ammonia daily maximum with a limit of 6.0 mg/L and a result of 9.2 mg/L.

If you have any questions concerning the attached DMR's, please contact me at (502) 919-5794.

Sincerely,

Scott Reed  
Process Supervisor

SR/CV 8/25.

Cc: V. Teague, B. Tinnel



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes

**Comments****Attachments**

Name	Type	Size
Hillview2CoverLetter8_25.pdf	pdf	33784.0

**Report Last Saved By****Hillview Sewer System Plant 2**

User: REED0325  
 Name: Scott Reed  
 E-Mail: reeds@louisvillemtd.org  
 Date/Time: 2025-09-23 12:44 (Time Zone: -04:00)

**Report Last Signed By**

User: REED0325  
 Name: Scott Reed  
 E-Mail: reeds@louisvillemtd.org  
 Date/Time: 2025-09-23 12:45 (Time Zone: -04:00)