



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

October 20th, 2025

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hillview 2 STP, KPDES No: KY00034169
Discharge Monitoring Report for September 2025.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview Plant #2 WQTC, for the month of September 2025.

There were no overflows or bypasses.

There was two exceedances for ammonia daily maximum with a limit of 6.0 mg/L, one with a result of 9.8 mg/L, the other with a result of 9.6 mg/L.

If you have any questions concerning the attached DMR's, please contact me at (502) 919-5794.

Sincerely,

Scott Reed
Process Supervisor

SR/CV 9/25.

Cc: V. Teague, B. Tinnel

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

| Parameter | | Monitoring Location | Field | Type | Description | Acknowledge |
|-----------|--------------------------------|---------------------|-----------------------------------------|------|--------------------------------------------------------------------------------------------------------------------------|-------------|
| Code | Name | | | | | |
| 00610 | Nitrogen, ammonia total [as N] | 1 - Effluent Gross | Quality or Concentration Sample Value 3 | Soft | The provided sample value is outside the permit limit. Please verify that the value you have provided is correct. | Yes |

Comments**Attachments**

| Name | Type | Size |
|------------------------------|------|---------|
| Hillview2CoverLetter9_25.pdf | pdf | 33416.0 |

Report Last Saved By**Hillview Sewer System Plant 2**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
 Name: Jonathan Baldrige
 E-Mail: jon.baldrige@louisvillemmsd.org
 Date/Time: 2025-10-21 10:04 (Time Zone: -04:00)

Report Last Signed By

User: REED0325
 Name: Scott Reed
 E-Mail: reeds@louisvillemmsd.org
 Date/Time: 2025-10-21 13:24 (Time Zone: -04:00)