



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

August 25th, 2025

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hillview 3 STP, KPDES No: KY0034177
Discharge Monitoring Report for July 2025.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview Plant #3 WQTC, for the month of July 2025.

There were no overflows or bypasses. There were two exceedances. One for daily maximum ammonia with a result of 12.7 mg/l with a limit of 6.0 mg/L. One for E. Coli 7 day geometric mean with a limit of 240 #/100mL with a result of 60000 #/100mL

If you have any questions concerning the attached DMR's, please contact me at (502) 919-5794

Sincerely,

Scott Reed
Process Supervisor

SR/HV3 6/25.

Cc: V. Teague, B. Tinnel

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments**Attachments**

Name	Type	Size
HV3CoverLetter7_25.pdf	pdf	37488.0

Report Last Saved By**Louisville and Jefferson County MSD**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
 Name: Jonathan Baldrige
 E-Mail: jon.baldrige@louisvillemmsd.org
 Date/Time: 2025-08-27 09:21 (Time Zone: -04:00)

Report Last Signed By

User: REED0325
 Name: Scott Reed
 E-Mail: reeds@louisvillemmsd.org
 Date/Time: 2025-08-27 10:03 (Time Zone: -04:00)