



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

December 22nd, 2025

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Hillview 3 STP, KPDES No: KY0034177  
Discharge Monitoring Report for November 2025.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview Plant #3 WQTC, for the month of November 2025.

There were no bypasses or overflows.

There were three exceedances. One for BOD weekly maximum with a result of 47ppm with a limit of 22.5ppm. One for e. Coli monthly average with a result of 142 #/100mL with a limit of 130 #/100mL. One for e. Coli weekly average with a result of 1533 #/100mL with a limit if 240 #/100mL

If you have any questions concerning the attached DMR's, please contact me at (502) 919-5794

Sincerely,

Scott Reed  
Process Supervisor

SR/HV3 11/25.

Cc: V. Teague, B. Tinnel



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
51040	E. coli	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes
51040	E. coli	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes

**Comments****Attachments**

Name	Type	Size
Hillview3Cover11_25.pdf	pdf	38473.0

**Report Last Saved By****Louisville and Jefferson County MSD**

User: REED0325  
 Name: Scott Reed  
 E-Mail: reeds@louisvillemd.org  
 Date/Time: 2025-12-22 13:12 (Time Zone: -05:00)

**Report Last Signed By**

User: REED0325  
 Name: Scott Reed  
 E-Mail: reeds@louisvillemd.org  
 Date/Time: 2025-12-26 10:28 (Time Zone: -05:00)