



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

October 20th, 2025

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Pioneer Village STP, KPDES No: KY0034185  
Discharge Monitoring Report for September 2025.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Pioneer Village WQTC, for the month of September 2025.

Overflow report attached.

There were no exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502) 919-5794.

Sincerely,

Scott Reed  
Process Supervisor

SR/PV 9/25.

Cc: V. Teague, B. Tinnel



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments****Attachments**

Name	Type	Size
Sept_2025_all_other_service_area.pdf	pdf	25279.0
PioneerVillageCoverLetter9_25.pdf	pdf	31202.0

**Report Last Saved By****Louisville and Jefferson County MSD**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG  
 Name: Jonathan Baldrige  
 E-Mail: jon.baldrige@louisvillemmsd.org  
 Date/Time: 2025-10-21 10:08 (Time Zone: -04:00)

**Report Last Signed By**

User: REED0325  
 Name: Scott Reed  
 E-Mail: reeds@louisvillemmsd.org  
 Date/Time: 2025-10-21 13:35 (Time Zone: -04:00)



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0102784	WQTCFF	FLOYDS FORK WQTC	FLOYDS FORK	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Main	96911C-V	817 GILLILAND RD	LONG RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3994396		9/12/2025 10:30:00 AM	BROADEN	BROADEN	REPAIRED - ISSUE RESOLVED	9/12/2025 12:00:00 AM	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	09/12/25 01:43 PM	

**Discharge Reporting:**

Discharge Amount:	90,000 GAL
Cause:	MECHANICAL FAILURE (16-INCH FORCE MAIN LINE BROKEN).
Clean Up:	AREA DISINFECTED WITH LIME.
Control Zone:	PLACED CONES AROUND THE IMPACTED AREA.
Impact:	SEWAGE VISIBLE AROUND PUMPED DISCHARGE SITE.
Repair:	REPAIRED THE FORCE MAIN BREAK.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

**Notifications:**

9/12/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
9/12/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**9/1/2025 12:00:00 AM to 9/30/2025 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0102784	WQTCFF	FLOYDS FORK WQTC	FLOYDS FORK	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSFF-ESWD	911 EASTWOOD FISHERVILLE RD	FLOYDS FORK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3994559		9/15/2025 10:00:00 AM	PARKER	PARKER	REPAIRED - ISSUE RESOLVED	9/15/2025 12:00:00 AM	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	09/16/25 06:00 AM	

**Discharge Reporting:**

Discharge Amount:	4,314 GAL
Cause:	MECHANICAL FAILURE (90-DEGREE ELBOW INSIDE BUILDING).
Clean Up:	MSD CONTRACTOR CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	ISOLATED MAIN AND HIRED CONTRACTOR TO MAKE REPAIRS.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

9/15/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
9/15/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**9/1/2025 12:00:00 AM to 9/30/2025 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0040126	WQTCKS	KSR WQTC	CEDAR CREEK	OLDHAM

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSKS-DISW	1815 N STHY 393	CURRYS FORK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3994163		9/10/2025 2:35:00 PM	PARKER	SMITH	QUEUED FOR INVESTIGATION / REPAIR	1/12/2023 12:00:00 AM	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	09/10/25 03:00 PM	

**Discharge Reporting:**

Discharge Amount:	1,750 GAL
Cause:	MECHANICAL FAILURE (W/O #3994153. DISCOVERED ILLICIT DUMPING OF POOL WATER INTO THE SYSTEM).
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	INSTRUCTED OLDHAM COUNTRY CLUB TO STOP DRAINING POOL INTO THE SYSTEM.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

9/11/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--



**IMSAST0004**  
**Overflow Report**  
**9/1/2025 12:00:00 AM to 9/30/2025 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	WQTCPV	PIONEER VILLAGE #1 WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSPV-HUHL	165 OCTAGON AVE	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4001296		9/25/2025 1:00:00 AM	BUTLER	BUTLER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	09/25/25 07:50 PM	

**Discharge Reporting:**

Discharge Amount:	65,200 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND IN THE STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

9/25/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
9/25/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004  
Overflow Report  
9/1/2025 12:00:00 AM to 9/30/2025 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0098540	WQTCCC	CEDAR CREEK WQTC	CEDAR CREEK	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTCCC	8405 CEDAR CREEK RD	CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4001375		9/25/2025 7:53:00 AM	BALDRIDGE		REPAIRED - ISSUE RESOLVED	9/25/2025 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	09/25/25 08:00 AM	

**Discharge Reporting:**

Discharge Amount:	77,000 GAL
Cause:	ELECTRICAL PROBLEM WITH MSD EQUIPMENT/ASSET (CUT CONTROL WIRES TO IPS. NOT ABLE TO HAVE BACK UP CONTROL)
Clean Up:	AREA DISINFECTED WITH LIME.
Control Zone:	PERMANENT SIGNS IN PLACE - NO ADDITIONAL CONTROL ZONE SET UP. PLACED TEMPORAY SIGNS ON OVERFLOW ACROSSS THE CREEK.
Impact:	SEWER FLOWED OUT OF MANHOLE ONTO GROUND. VERY LITTLE DEBRIS.
Repair:	PLACED PUMPS IN HAND, PUMP IPS DOWN. BYPASS STOPPED.
Public Notification:	N/A.

**Notifications:**

9/25/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
9/25/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION