



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

June 25th, 2025

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Willabrook STP, KPDES No: KY0094307
Discharge Monitoring Report for May 2025.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Willabrook WQTC, for the month of May 2025.

Overflow report attached

There were no bypasses. There were no exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither
Process Supervisor

CAS/CV 5/25.

Cc: V. Teague, B. Tinnel

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments**Attachments**

Name	Type	Size
WILLABROOK_OVERFLOW_REPORT_5_25.pdf	pdf	116160.0
WILLABROOK_COVER_5_25.pdf	pdf	32283.0

Report Last Saved By**Louisville and Jefferson County MSD**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG
 Name: Charles Smither
 E-Mail: alex.smither@louisvillemmsd.org
 Date/Time: 2025-06-25 13:36 (Time Zone: -04:00)

Report Last Signed By

User: ALEX.SMITHER@LOUISVILLEMSD.ORG
 Name: Charles Smither
 E-Mail: alex.smither@louisvillemmsd.org
 Date/Time: 2025-06-25 13:36 (Time Zone: -04:00)



**IMSAST0004
Overflow Report**

5/1/2025 12:00:00 AM to 5/31/2025 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	MSD0511	WILLABROOK	BROOKS RUN	

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3944867		5/17/2025 12:24:00 AM	BROADEN	BROADEN	DOCUMENTED	1/1/1992 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	05/17/25 08:44 AM	

Discharge Reporting:

Discharge Amount:	9,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE / DEBRIS / SOLIDS / PERSONAL HYGIENE PRODUCTS FOUN IN THE AREA.
Repair:	REPORTED BY BASE 4 WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

5/17/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/17/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004
Overflow Report**

5/1/2025 12:00:00 AM to 5/31/2025 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	MSD0511	WILLABROOK	BROOKS RUN	

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3948392		5/20/2025 10:15:00 PM	BUTLER	BUTLER	DOCUMENTED	1/1/1992 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	05/21/25 07:15 AM	

Discharge Reporting:

Discharge Amount:	18,800 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED - FACILITY UNDER ELEVATED CREEK LEVEL.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

5/21/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/21/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION