



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

August 19, 2025

Crystal Dennis
300 Sower Blvd., 3rd Floor.
Frankfort, Kentucky 40601

**RE: Cedar Creek WQTC, KPDES No: KY0098540
Discharge Monitoring Report for July 2025.**

Dear Mrs. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Cedar Creek WQTC, for the month of July 2025.

There were no exceedances, overflows or bypasses to report.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6717.

Sincerely,

Jon Baldrige
Process Supervisor

JOB/ Cedar Creek. 07/25.

Enclosures

Cc: V. Graves
B. Tinnell

					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 131.0	=	181.0	26 - lb/d	=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req. <= 626.0 MO AVG	<=	939.0 MX WK AV	26 - lb/d	<=	10.0 MO AVG	<=	15.0 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - 24 Hour Composite		
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample =				=	135.0	=	203.0	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req.					Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - 24 Hour Composite		
					Value NODI													
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample =				=	98.0			23 - %	0	01/30 - Monthly	CA - Calculated		
					Permit Req. >=				>=	85.0 MO AV MN			23 - %	0	01/30 - Monthly	CA - Calculated		
					Value NODI													
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample =				=	99.0			23 - %	0	01/30 - Monthly	CA - Calculated		
					Permit Req. >=				>=	85.0 MO AV MN			23 - %	0	01/30 - Monthly	CA - Calculated		
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
CCMOR072025.pdf	pdf	128272.0
SKM_C3351i25081908240.pdf	pdf	33131.0

Report Last Saved By

Cedar Creek WQTC MSD

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
 Name: Jonathan Baldrige
 E-Mail: jon.baldrige@louisvillemmsd.org
 Date/Time: 2025-08-19 08:40 (Time Zone: -04:00)

Report Last Signed By

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
 Name: Jonathan Baldrige
 E-Mail: jon.baldrige@louisvillemmsd.org
 Date/Time: 2025-08-19 10:54 (Time Zone: -04:00)

