



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

April 21, 2025

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE:   Floyds Fork WQTC, KPDES No: KY0102784  
      Discharge Monitoring Report for March 2024.**

Dear Mrs. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Floyds Fork WQTC, for the month of March 2024.

There were no exceedances or bypasses to report.

Also attached is a Monthly Discharge report.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6717.

Sincerely,

Jon Baldridge  
Process Supervisor

  
JOB/ Floyds Fork. 3/24.

Enclosures

Cc:   V. Graves  
      B. Tinnell

NAME OF TREATMENT PLANT FLOYDS FORK COUNTY JEFFERSON MONTH OF: March 2025  
KPDES PERMIT NUMBER KY0102784 PLANT CAPACITY 3.5 MGD RECEIVING STREAM FLOYDS FORK

DATE	TOTAL FLOW (MILLION GALLONS)	RAW SEWAGE		pH		SETTLEABLE SOLIDS (mg/L)		DISSOLVED OXYGEN (mg/L)		SUSPENDED SOLIDS (mg/L)		5 DAY CBOD (mg/L)		ACTIVATED SLUDGE			AERATION BASIN				SLUDGE HANDLING						FINAL			Total Nitrogen	TOTAL FLOW (MILLION GALLONS)						
		GRIT REMOVED (CUBIC FEET)	SCREENINGS (CUBIC FEET)	RAW	FINAL	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	STREAM ABOVE	FINAL EFFLUENT	STREAM BELOW	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RETURN		WASTED	DISSOLVED OXYGEN (mg/L)	MLSS (mg/L) X 1000	MLVSS (mg/L) X 1000	SETTLED SLUDGE VOLUME		RAW		HAULED				PHOSPHORUS, TOTAL (mg/L)	NH3-N (mg/L)	ECOLI			
																		GAL/DAY X 1000	MLSS X1000					GAL/DAY X 1000	30 MIN.	60 MIN.	GALLONS X 1000	% DRY SOLIDS	% VOLATILE SOLIDS						% DRY SOLIDS	% VOLATILE SOLIDS	WITHDRAWN GALLONS X 1000
1	3.739																	1.43		60000	5.3																3.206008
2	3.677																	1.37		60000	5.7															3.218014	
3	3.489			7.5							607		3	236		3		1.41	8240	60000	5.4	3070	2510	810							107100	0.20	1.30	1	13.6	2.987559	
4	3.490			7.5	8.0				10.9									1.46	9660	90000	4.3	3650	2960	830							107100					2.924198	
5	4.004			7.8														1.55	11020	90000	3.7	3550	2930	800							94500					3.329441	
6	3.679			7.5														1.59	10680	100000	5.7	3280	2700	810							100800					3.137562	
7	3.570			7.5														1.61	10200	70000	5.4	3210	2640	830							107100					3.00179	
8	3.639																	1.46		70000	5			840												3.13508	
9	3.680																	1.39		70000	4.6			800												3.183814	
10	3.510			7.6	8.3				10.3		550		3	101		2		1.45	11110	70000	3.7	3060	2520	800							75600	0.20	1.60	1	13.4	3.004595	
11	2.974			7.5														0.89	9100	70000	3.9	3110	2670	800							107100					2.941	
12	3.107			7.6														1.66	5100	70000	3.3	3040	2610	780							107100					2.863292	
13	3.614			7.8														2.46	5720		5.8	2850	2380	830							107100					2.80113	
14	3.086			7.3														2.41	6120		4.9	3590	2990	870							75600					2.764	
15	6.393																	2.67		70000	4.3			850												5.958	
16	14.675																	4.11		70000	8.2			500												12.561	
17	7.517			7.3	8.6				10.8		211		3	83		3		4.11	7490		7	3060	2520	810							107100	0.20	0.44	1	7.74	6.545	
18	5.885			7.6														3.5	5930	90000	7	2910	2300	820							107100					4.774	
19	5.328			7.5														3.3	6000	100000	6.8	2210	1860	660							88200					4.081648	
20	5.593			7.5														3.3	5660	100000	5.3	3090	2600	870							107100					4.390929	
21	4.434			7.6														3.4	4840	110000	5.5	2890	2450	880							107100					3.761363	
22	4.217																	3.63		100000	5.1			880												3.596248	
23	4.654																	3.39		90000	5.3			880												3.982586	
24	5.779			7.5	8.6				10.6		304		9	162		3		3.21	5700	90000	6.4	2820	2320	800							107100	0.41	0.79	3	10	4.957072	
25	4.902			7.4														3.28	6060	100000	7.9	3120	2610	890							107100					3.976429	
26	4.300			7.5														3.36	7660	90000	5.6	3380	2890	900							75600					3.637969	
27	4.122			7.6														3.3	5830	110000	4.1	3290	2760	900							107100					3.470892	
28	3.847			7.7														3.4	5780	100000	2.4	3380	2870	900							107100					3.319602	
29	3.798																	3.37		100000	4.2			900												3.165432	
30	4.590																	3.47		50000	4.3			900												3.590886	
31	7.825			7.4														4.54	5670	50000	7	2620	2200	850							107100					6.970006	
Tot.	147.12																	81.48														2116800					125.24
Avg.	4.746			7.5	8.4				10.7		418		5	146		3		2.628	7313	82143	5.261	3104	2585	827.2							68283.9	0.25	1.03	1	11.19	4.040	

RESIDENTIAL  
COMMERCIAL  
INDUSTRIAL  
45197  
FLOW  
33875  
CBOD  
78781  
TSS  
Micheal Stephenson  
OPERATOR  
9616  
CERT. NO.

TOTAL NUMBER OF SEWER CONNECTIONS  
SEWER CONNECTIONS 0 X 4 = 0 SEWERED POPULATION

502-540-6000  
PLANT TELEPHONE

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #:  
Major:

KY0102784  
Yes

Permittee:  
Permittee Address:

Floyds Fork WQTC MSD  
700 W Liberty St  
Louisville, KY 40203

Facility:  
Facility Location:

FLOYDS FORK WQTC MSD  
1100 BLUE HERON RD  
LOUISVILLE, KY 40245

Permitted Feature:

001  
External Outfall

Discharge:

001-1  
MUNICIPAL DISCHARGE

Report Dates & Status

Monitoring Period:

From 03/01/25 to 03/31/25

DMR Due Date:

04/28/25

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:  
Last Name:

James  
Parrott

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	10.0					19 - mg/L	0	01/07 - Weekly	GR - Grab
					Permit Req.						>=	7.0 INST MIN					19 - mg/L			
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	8.0			=	8.6	12 - SU	0	01/07 - Weekly	GR - Grab
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU			
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	199.0	=	434.0	26 - lb/d			=	5.0	=	9.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	1626.0 MO AVG	<=	2439.0 MX WK AV	26 - lb/d			<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L			
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample								=	418.0	=	607.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L			
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	11.0	=	14.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L			
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample	=	37.6	=	46.8	26 - lb/d			=	1.0	=	1.6	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	163.0 MO AVG	<=	244.0 MX WK AV	26 - lb/d			<=	3.0 MO AVG	<=	4.5 MX WK AV	19 - mg/L			
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	=	11.0	=	19.7	26 - lb/d			=	0.3	=	0.4	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	27.1 MO AVG	<=	40.7 MX WK AV	26 - lb/d			<=	0.5 MO AVG	<=	0.75 MX WK AV	19 - mg/L			
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	4.746	=	14.675	03 - MGD								0	99/99 - Continuous	CN - Continuous
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD										
					Value NODI															
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	4.04	=	12.561	03 - MGD								0	99/99 - Continuous	CN - Continuous
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD										
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	1.0	=	3.0	13 - #/100mL	0	01/07 - Weekly	GR - Grab
					Permit Req.								<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL			

					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	120.0	=	188.0	26 - lb/d		=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	325.0 MO AVG	<=	488.0 MX WK AV	26 - lb/d		<=	6.0 MO AVG	<=	9.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample							=	146.0	=	236.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.								Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample					=	98.0					23 - %	0	01/30 - Monthly	CA - Calculated
					Permit Req.					>=	85.0 MO AV MN					23 - %		01/30 - Monthly	CA - Calculated
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample					=	99.0					23 - %	0	01/30 - Monthly	CA - Calculated
					Permit Req.					>=	85.0 MO AV MN					23 - %		01/30 - Monthly	CA - Calculated
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
ffbiorptfeb2025.pdf	pdf	7845068.0
March_2025_All_other_service.pdf	pdf	153562.0
FloydsForkCoverletter.pdf	pdf	35262.0
FFLIMSPCSSPREADSHEET032025.xls	xls	185344.0
FFMOR032025.xls	xls	342528.0

Report Last Saved By

Floyds Fork WQTC MSD

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG

Name: Jonathan Baldridge

E-Mail: jon.baldridge@louisvillemسد.org

Date/Time: 2025-04-22 08:25 (Time Zone: -04:00)

Report Last Signed By

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG

Name: Jonathan Baldridge

E-Mail: jon.baldridge@louisvillemسد.org

Date/Time: 2025-04-22 08:25 (Time Zone: -04:00)

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z			
1						Floyds Fork WTP Data - March-25														March			2025						
2		Influent Flow (MGD)	Plant Effluent Flow (MGD)	Sec/Biol Flow (MGD)	Sec. Bypass Flow (MGD)	Infl. CBOD (mg/L)	Effl. CBOD (mg/L)	Infl. TSS (mg/L)	Effl. TSS (mg/L)	Infl. NH3 (mg/L)	Effl. NH3 (mg/L)	< >	FECAL (Colonies)	Infl. T-Phos. (mg/L)	Effl. T-Phos. (mg/L)	Effl. pH	Effl. DO (mg/L)	Eff. TKN (mg/L)	< >	Total Res. Cl2 (mg/L)	< >	Cadmium Total Recov. Monthly	< >	Eff Cr+6 (Hex. Cr)	< >	Eff Cyanide free amen.			
3	DATE																												
5	2025-03-01	3.206	3.739									<							<		<				<				
6	2025-03-02	3.218	3.677									<							<		<				<				
7	2025-03-03	2.988	3.489			236	3	607	3	22.1	1.3	<			0.2			2.2	<		<				<				
8	2025-03-04	2.924	3.490									<				8	10.9		<		<				<				
9	2025-03-05	3.329	4.004									<							<		<				<				
10	2025-03-06	3.138	3.679									<							<		<				<				
11	2025-03-07	3.002	3.570									<							<		<				<				
12	2025-03-08	3.135	3.639									<							<		<				<				
13	2025-03-09	3.184	3.680									<							<		<				<				
14	2025-03-10	3.005	3.510			101	2	550	3	24.2	1.6	<			0.2	8.3	10.3	3.4	<		<				<				
15	2025-03-11	2.941	2.974									<							<		<				<				
16	2025-03-12	2.863	3.107									<							<		<			0.005	<				
17	2025-03-13	2.801	3.614									<							<		<				<				
18	2025-03-14	2.764	3.086									<							<		<				<				
19	2025-03-15	5.958	6.393									<							<		<				<				
20	2025-03-16	12.561	14.675									<							<		<				<				
21	2025-03-17	6.545	7.517			83	3	211	3	7.4	0.44	<			0.2	8.6	10.8	1.6	<		<				<				
22	2025-03-18	4.774	5.885									<							<		<				<				
23	2025-03-19	4.082	5.328									<							<		<				<				
24	2025-03-20	4.391	5.593									<							<		<				<				
25	2025-03-21	3.761	4.434									<							<		<				<				
26	2025-03-22	3.596	4.217									<							<		<				<				
27	2025-03-23	3.983	4.654									<							<		<				<				
28	2025-03-24	4.957	5.779			162	3	304	9	14.2	0.79	<			0.408	8.6	10.6	2.9	<		<				<				
29	2025-03-25	3.976	4.902									<							<		<				<				
30	2025-03-26	3.638	4.300									<							<		<				<				
31	2025-03-27	3.471	4.122									<							<		<				<				
32	2025-03-28	3.320	3.847									<							<		<				<				
33	2025-03-29	3.165	3.798									<							<		<				<				
34	2025-03-30	3.591	4.590									<							<		<				<				
35	2025-03-31	6.970	7.825									<							<		<				<				
36	TOTAL	125.237	147.117	0.00	0.00																								
37	AVERAGE*	4.040	4.75	0.000	0.000	146	3	418	5	17	1	<	0	0.00	0.3	8.4	10.7		<	0.000	<	0.0	<	0.01	<	0.000			
38	MINIMUM	2.764	2.974	0.000	0.000	83.00	2.00	211.00	3.00	7.40	0.44	<	0	0.00	0.2	8.0	10		<	0.000	<	0.0	<	0.01	<	0.000			
39	MAXIMUM	12.561	14.68	0.000	0.000	236.00	3.00	607.00	9.00	24.20	1.60	<	0	0.00	0.4	8.6	10.9		<	0.000	<	0.0	<	0.01	<	0.000			
40	*For Fecal: Calculation is for Geometric Mean (not Average).																												
41	Max.Wk Avg	6.010	7.118	0.000	0.000	236	3	607	9	24	1.6		** AS = Above Stream; BS = Below Stream (in receiving stream)			0.4													
42	Exceed.	6	12	0	0		0		0		2		0	0	0	0	0												
43	MxWkAvg																												
44	Exceed						0		0		0		0		0	0													
45	Wk Avg						0		0		0		0		0	0													
46	Total KLBS Treated					0.000		0.000								0	0	0											
47	Winter Limits																												
48																													

Month

	AA	AB	AC	AD	AE	AF	AG	AH	AI	AJ	AK	AL	AM	AN	AO	AP	AQ	AR	AS	AT	AU	AV	AW	AX	AY	AZ
1																										
2	Effl.	Sec.Eff.	Sec.Eff.	Sec.Eff.	Pri.Effluent	Pri.Effluent	Pri.Effluent	Influent	Effluent	Influent	Effluent	Influent	Eff	Inf	Eff.	Effluent	Sec.Eff.	Sec.Eff.	Sec.Eff.	Pri.Effluent	Pri.Effluent	Pri.Effluent	% Remov	% Remov	<	Toxicity
3	Hardness	BOD	TSS	NH3	BOD	TSS	NH3	CBOD	CBOD	TSS	TSS	NH3	NH3	Phos.	Phos.	TKN	BOD	TSS	NH3	BOD	TSS	NH3	BOD	TSS	>	Units
4	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	(mg/L)	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds	pounds		
5																										
6																										
7								5880.233	87.29571	15124.16	87.29571	550.6489	37.82814		5.819714	64.01685							0.987288	0.995058		
8																										
9																										
10																										
11																										
12																										
13																										
14								2530.891	58.54883	13782.08	87.82325	606.4114	46.83907		5.854883	99.53302							0.980198	0.994545		
15																										
16																										
17																										
18																										
19																										
20																										
21								4530.58	188.0753	11517.5	188.0753	403.9312	27.58438		12.53836	100.3068							0.963855	0.985782		
22																										
23																										
24																										
25																										
26																										
27																										
28								6697.401	144.5907	12567.96	433.7722	587.0561	38.07556		19.66434	139.771							0.981481	0.970395		
29																										
30																										
31																										
32																										
33																										
34																										
35																										
36								19639	478.51	52991.7	796.97	2148.0	150	0.0	43.88	403.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		
37	0.0	0.0	0.0	0.0	0.0	0.0	0.0	4910	120	13248	199	537	38	0.0	11.0	100.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	98%	99%
38	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2531	59	11517	87	403.9	28	0.0	5.8	64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	96.4%	97.0%
39	0.0	0.0	0.0	0.0	0.0	0.0	0.0	6697	188	15124	434	606.4	47	0.0	19.7	139.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		0.00
40								4	4	4	4	4	4	0	4	4	0	0	0	0	0	0	0	0		
41								6697	188	15124	434	606	47	0	19.7	140	0	0	0	0	0	0	0	0		
42									0		0		0		0	0	0	0	0	0	0	0	0	0	0	0
43									0		0		0		0	0	0	0	0	0	0	0	0	0	0	0
44									0		0		0		0	0	0	0	0	0	0	0	0	0	0	0
45																										
46																										
47																										
48																										

	BA	BB	BC	BD	BE	BF	BG	BH	BI	BJ	BK	BL	BM	BN	BO	BP	BQ	BR	BS	BT	BU	BV	BW	BX	
1				Biomonitoring Data																					
2		Zinc, Total Recov. (mg/L)		Lead, Total Recov. (mg/L)		Copper, Total Recov. (mg/L)		Mercury, Total Recov. (mg/L)		Cadmium, Total Recov. (mg/L)	Total Hardness (mg/L)		Cadmium, Dissolved (mg/L)		Copper, Dissolved (mg/L)		Lead Dissolved (mg/L)		Zinc Dissolved (mg/L)	ECOL (Colonies)	Total Nitrogen (mg/L)	Pri.Eff.Bypass BOD (mg/L)	Pri.Eff.Bypass TSS (mg/L)	Pri.Eff.Bypass NH3N (mg/L)	
3	<	>	<	<	<	<	<	<	<	<	<	<	<	<	<	<	<	<	<						
4																									
5	<		<				<		<			<		<		<		<							
6	<		<				<		<			<		<		<		<			1	13.6	0.00	0.00	0
7	<		<				<		<			<		<		<		<							
8	<		<				<		<			<		<		<		<							
9	<		<				<		<			<		<		<		<							
10	<		<				<		<			<		<		<		<							
11	<		<				<		<			<		<		<		<							
12	<		<				<		<			<		<		<		<							
13	<		<				<		<			<		<		<		<							
14	<		<				<		<			<		<		<		<		1	13.4	0.00	0.00	0	
15	<		<				<		<			<		<		<		<							
16	<		<				<		<			<		<		<		<							
17	<		<				<		<			<		<		<		<							
18	<		<				<		<			<		<		<		<							
19	<		<				<		<			<		<		<		<							
20	<		<				<		<			<		<		<		<							
21	<		<				<		<			<		<		<		<		1	7.74	0.00	0.00	0	
22	<		<				<		<			<		<		<		<							
23	<		<				<		<			<		<		<		<							
24	<		<				<		<			<		<		<		<							
25	<		<				<		<			<		<		<		<							
26	<		<				<		<			<		<		<		<							
27	<		<				<		<			<		<		<		<							
28	<		<				<		<			<		<		<		<		3	10	0.00	0.00	0	
29	<		<				<		<			<		<		<		<							
30	<		<				<		<			<		<		<		<							
31	<		<				<		<			<		<		<		<							
32	<		<				<		<			<		<		<		<							
33	<		<				<		<			<		<		<		<							
34	<		<				<		<			<		<		<		<							
35	<		<				<		<			<		<		<		<							
36																									
37		0.000	<	0.00	<	0.000	<	0	<	0	0	<	0	<	0	<	0	<	0	1	11	0	0	0	
38		0.000	<	0.00	<	0.000	<	0	<	0	0	<	0	<	0	<	0	<	0	1	8	0	0	0	
39	<	0.000	<	0.00	<	0.000	<	0	<	0	0	<	0	<	0	<	0	<	0	3	14	0	0	0	
40																									
41																				3	14				
42																				0					
43																				0					
44																				0					
45																				0					
46																									
47																									
48																									



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	NA

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Manhole	119477	6615 ADAM RIDGE PL	DEREK R. GUTHRIE	FERN CREEK	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISDW: DRY WEATHER DISCHARGE	3920748		3/27/2025 1:05:00 PM	VAUGHAN	GIBSON	REPAIRED - ISSUE RESOLVED	3/27/2025 12:00:00 AM	OBSTRUCTION-NOT GREASE / ROOTS	UNAUTHORIZED DISCHARGE-WATERS	03/27/25 01:34 PM	MAIN

**Discharge Reporting:**

Discharge Amount:	2,400 GAL
Cause:	OBSTRUCTION IN MAIN SEWER.
Clean Up:	DISCLN 3920773.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/WATER DISCHARGING FROM MANHOLE.
Repair:	ROOT CUTTING MAIN SEWER TO RESTORE FLOW 3920760.
Public Notification:	ADVISED CUSTOMER ON SITE.

**Notifications:**

3/28/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---





**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0106143	MSD0407	OHIO RIVER	OHIO RIVER	NA

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Main	123193-V	12905 WOODSIDE DR	OHIO RIVER	POND CREEK	DITCH

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISDW: DRY WEATHER DISCHARGE	3920192		3/24/2025 7:15:00 PM	PARKER	PARKER	REPAIRED - ISSUE RESOLVED	3/24/2025 12:00:00 AM	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	03/26/25 08:17 AM	

**Discharge Reporting:**

Discharge Amount:	3,850 GAL
Cause:	STRUCTURAL FAILURE FORCE MAIN BREAK.
Clean Up:	MSD CONTRACTOR CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED BARRICADES AND CAUTION TAPE AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND ON THE GROUND.
Repair:	CONTACTED CONTRATORS TO MAKE REPAIRS AND HAUL STATION.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

**Notifications:**

3/25/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/25/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	NA

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Manhole	61304	8935 LA COSTA RD	DEREK R. GUTHRIE	FERN CREEK	DITCH

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISDW: DRY WEATHER DISCHARGE	3906031		3/3/2025 7:45:00 PM	GRIGSBY JR		REPAIRED - ISSUE RESOLVED	3/3/2025 12:00:00 AM	ROOTS	UNAUTHORIZED DISCHARGE- WATERS	03/03/25 10:22 PM	

**Discharge Reporting:**

Discharge Amount:	1 GAL
Cause:	ROOTS IN MAIN SEWER.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	MSD PERSONNEL ADVISED THE CUSTOMER TO AVOID CONTACT WITH SEWAGE.
Impact:	OBSERVED BY MSD PERSONNEL.
Repair:	ROOT CUT MAIN SEWER GOT OPEN RETURNED TO NORMAL FLOW.
Public Notification:	ADVISED THE CUSTOMER ON SITE.

**Notifications:**

3/4/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
----------------	--------	---



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	NA

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Manhole	93217	12304 DOMINION WAY	CEDAR CREEK		

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908711		3/16/2025 2:00:00 PM	YARBROUGH	YARBROUGH	QUEUED FOR INVESTIGATION / REPAIR	3/16/2025 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/16/25 02:50 PM	SUR

**Discharge Reporting:**

Discharge Amount:	10 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND AROUND MANHOLE.
Repair:	ADVISED TO CALL BACK AFTER 24 HRS IF PROBLEM PERSISTS.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/17/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034151	MSD0506	BCSD HILLVIEW #1	TANYARD BRANCH	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Treatment Plant	MSD0506	253 LEES LN	BCSD HILLVIEW #1	TANYARD BRANCH	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908666		3/16/2025 2:45:00 AM	SUTHERLAND		DOCUMENTED	1/8/2022 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/16/25 06:40 PM	

**Discharge Reporting:**

Discharge Amount:	23,750 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	INF DISCHARGE ON GROUND INSIDE PLANT FROM MANHOLE.
Repair:	INVESTIGATION INDICATED THAT ADDITIONAL REPAIRS WERE NOT REQUIRED BY MSD.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/16/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034169	MSD0507	BCSD HILLVIEW #2	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Treatment Plant	MSD0507	376 NORWOOD DR	BCSD HILLVIEW #2	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908611		3/15/2025 3:30:00 PM	SUTHERLAND		DOCUMENTED	12/6/2021 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/16/25 08:00 PM	

**Discharge Reporting:**

Discharge Amount:	87,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	INF DISCHARGING TO CONCRETE DITCH ON PLANT.
Repair:	INVESTIGATION INDICATED THAT ADDITIONAL REPAIRS WERE NOT REQUIRED BY MSD.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/16/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034169	MSD0507	BCSD HILLVIEW #2	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Treatment Plant	MSD0507	376 NORWOOD DR	BCSD HILLVIEW #2	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3921064		3/30/2025 10:18:00 PM	BALDRIDGE		DOCUMENTED	12/6/2021 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/31/25 08:43 AM	

**Discharge Reporting:**

Discharge Amount:	221,190 GAL
Cause:	POWER FAILURE NO INFLUENT PUMPS RUNNING.
Clean Up:	WILL GET EIC TO CLEAN CONCRETE DITCH IN PLANT.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY
Impact:	INFLUENCE DISCHARGED TO CONCRETE DITCH ON PLANT[OVERFLOW CONTAINED ON MSD PROPERTY
Repair:	POWER WAS RESTORED AND PUMPS WERE ABLE TO PUMP WELL DOWN.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA

**Notifications:**

3/31/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/31/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Treatment Plant	MSD0508	126 WESTERN RD	BCSD HILLVIEW #3	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3921066		3/30/2025 10:45:00 PM	BALDRIDGE		DOCUMENTED	3/29/2023 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE- WATERS	03/31/25 01:05 AM	

**Discharge Reporting:**

Discharge Amount:	52,305 GAL
Cause:	POWER OUTAGE (LG&E).
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	INF DISCHARGING FROM MANHOLE TO CREEK.
Repair:	POWER RESTORED INFLUENTS PUMOS WERE ABLE TO KEEP UP.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/31/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/31/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004  
Overflow Report  
3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034801	MSD0509	BULLITT HILLS	TANYARD BRANCH	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0509	233 MAYFLOWER RD	BULLITT HILLS	TANYARD BRANCH	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3908667		3/16/2025 3:45:00 AM	SUTHERLAND		DOCUMENTED	3/9/2023 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/16/25 05:55 PM	

**Discharge Reporting:**

Discharge Amount:	42,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP REQUIRED.
Control Zone:	INSIDE OF PLANT FENCE.
Impact:	INF DISCHARGING WITH EFFLUENT TO DITCH ON.
Repair:	FLOW WENT DOWN ALLOWED PUMPS TO CATCH UP.
Public Notification:	TEMPORARY SIGN NEAR FENCE BY DISCHARGE.

**Notifications:**

3/16/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION





**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Treatment Plant	MSD0512	815 JOHN HARPER HWY	PIONEER VILLAGE #1	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908668		3/16/2025 4:06:00 AM	SUTHERLAND		DOCUMENTED	3/8/2023 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/16/25 01:30 PM	

**Discharge Reporting:**

Discharge Amount:	42,300 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	INSIDE OF PLANT FENCE.
Impact:	INF DISCHARGING FROM MANHOLE DITCH ON PLANT.
Repair:	FLOW WENT DOWN FROM RAIN EVENT, INF PUMPS WERE ABLE TO CATCH UP.
Public Notification:	TEMPORARY SIGN NEAR FENCE BY DISCHARGE.

**Notifications:**

3/16/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Treatment Plant	MSD0512	815 JOHN HARPER HWY	PIONEER VILLAGE #1	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3921065		3/30/2025 10:44:00 PM	BALDRIDGE		DOCUMENTED	3/8/2023 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/31/25 02:10 AM	

**Discharge Reporting:**

Discharge Amount:	72,100 GAL
Cause:	POWER OUTAGE (LG&E).
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	INFLUENT DISCHARGING FROM MANHOLE TO CREEK.
Repair:	POWER WAS RESTORED AND INFLUENT PUMPS WERE ABLE TO PUMP AND KEEP UP.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED ARE.

**Notifications:**

3/31/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/31/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	MSD0277	DEREK R. GUTHRIE			OHIO RIVER		NA				
Facility Type	Facility ID	Facility Address		If Pump Station, Name of Station			Recieving Stream		Discharge To		
Sewer Lift Station	SSPSDG-CIND	9114 CINDERELLA LN	DEREK R. GUTHRIE			FISHPOOL CREEK		DITCH			
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3908683		3/16/2025 4:05:00 PM	MILES	MILES	BEYOND APPROVED DESIGN STORM	3/16/2025 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	03/16/25 04:07 PM	

**Discharge Reporting:**

Discharge Amount:	21,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR.
Repair:	INVESTIGATION INDICATED THAT ADDITIONAL REPAIRS WERE NOT REQUIRED BY MSD.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/16/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034169	MSD0507	BCSD HILLVIEW #2	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSH2-HLV2	319 WINSTON CT	BCSD HILLVIEW #2	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3921070		3/30/2025 11:18:00 PM	BROADEN	BROADEN	DOCUMENTED	12/11/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/31/25 08:55 AM	

**Discharge Reporting:**

Discharge Amount:	22,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED – MAGNITUDE OF STORM FLUSHED SOLIDS AND DEBRIS FROM SITE
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/31/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/31/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSH3-HLV3	169 SUMMERS DR	BCSD HILLVIEW #3	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908661		3/15/2025 9:40:00 PM	BUTLER	TIMMERING	DOCUMENTED	12/9/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/16/25 04:40 AM	

**Discharge Reporting:**

Discharge Amount:	21,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND IN THE STREAM.
Repair:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/16/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSH3-HLV3	169 SUMMERS DR	BCSD HILLVIEW #3	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908680		3/16/2025 9:25:00 AM	MILES	MILES	DOCUMENTED	12/9/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/16/25 03:48 PM	

**Discharge Reporting:**

Discharge Amount:	18,950 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND IN THE STREAM.
Repair:	NO REPAIR REQUIRED.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/16/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSH3-HLV3	169 SUMMERS DR	BCSD HILLVIEW #3	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3921072		3/30/2025 11:40:00 PM	BROADEN	BROADEN	DOCUMENTED	12/9/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/31/25 08:57 AM	

**Discharge Reporting:**

Discharge Amount:	7,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND IN THE STREAM.
Repair:	NO REPAIR REQUIRED.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/31/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/31/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0106143	MSD0407	OHIO RIVER	OHIO RIVER	NA

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSOR-CBRD	13301 STHY 329	OHIO RIVER	HARRODS CREEK	GROUND

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908703		3/16/2025 3:11:00 PM	MILES	MILES	QUEUED FOR INVESTIGATION / REPAIR	3/24/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/16/25 03:18 PM	

**Discharge Reporting:**

Discharge Amount:	7,075 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/17/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--





**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSPV-HUHL	165 OCTAGON AVE	PIONEER VILLAGE #1	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3906298		3/5/2025 2:10:00 AM	JACKSON	BUTLER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/06/25 01:48 PM	

**Discharge Reporting:**

Discharge Amount:	27,200 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEAN AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE DEBRIS/SOLIDS /PERSONAL HYGIENE PRODUCTS FOUND AROUND AREA.
Repair:	SITE FOUND DURING RAIN EVENT RECON. WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/5/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/5/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSPV-HUHL	165 OCTAGON AVE	PIONEER VILLAGE #1	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908564		3/15/2025 4:15:00 PM	BUTLER	BUTLER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/18/25 09:11 PM	

**Discharge Reporting:**

Discharge Amount:	406,100 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND IN THE STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/16/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSPV-HUHL	165 OCTAGON AVE	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3920021		3/23/2025 9:33:00 PM	MILES	MILES	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/26/25 08:07 AM	

**Discharge Reporting:**

Discharge Amount:	80,200 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PLACED PERMANENT AND TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED OULETS SUBMERGED.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/24/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/24/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSPV-HUHL	165 OCTAGON AVE	PIONEER VILLAGE #1	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3921076		3/31/2025 12:40:00 AM	BROADEN	BROADEN	DOCUMENTED	12/21/2022 12:00:00 AM	POWER OUTAGE (LG&E)	UNAUTHORIZED DISCHARGE- WATERS	03/31/25 04:40 AM	

**Discharge Reporting:**

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PLACED PERMANENT AND TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED OULETS SUBMERGED.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/31/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/31/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2025 12:00:00 AM to 3/31/2025 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0094307	MSD0511	WILLABROOK	BROOKS RUN	

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>If Pump Station, Name of Station</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD	WILLABROOK	BROOKS RUN	GROUND

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	3908584		3/15/2025 6:28:00 PM	BUTLER	BUTLER	DOCUMENTED	1/1/1992 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	03/18/25 09:14 PM	

**Discharge Reporting:**

Discharge Amount:	126,400 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED - FACILITY UNDER ELEVATED CREEK LEVEL.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/16/25 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/25 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION