



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

December 22nd, 2025

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Ohio River STP, KPDES No: KY0106143
Discharge Monitoring Report for November 2025.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Ohio River STP, for the month of November 2025.

Overflow report attached.

There were no bypasses or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

A handwritten signature in black ink, appearing to be 'AS' with a long horizontal stroke extending to the right.

Alex Smither
Process Supervisor

CAS/OR 11/25.

Cc: V. Teague, B. Tinnel

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #:
Major:

KY0106143
Yes

Permittee:
Permittee Address:

Louisville and Jefferson County MSD
700 W Liberty St
Louisville, KY 40203

Facility:
Facility Location:

OHIO RIVER WWTP
1901 LANDING RD
GOSHEN, KY 40026

Permitted Feature:

001
External Outfall

Discharge:

001-1
Domestic Wastewater from a Publicly Owned Treatment Works

Report Dates & Status

Monitoring Period:

From 11/01/25 to 11/30/25

DMR Due Date:

12/28/25

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:
Last Name:

Tony
Parrott

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	9.0					19 - mg/L	0	01/07 - Weekly	GR - Grab
					Permit Req.						>=	2.0 INST MIN					19 - mg/L			
					Value NODI															
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	11.0	=	12.0	26 - lb/d			=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	375.0 MO AVG	<=	563.0 MX WK AV	26 - lb/d			<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L			
					Value NODI															
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample								=	184.0	=	282.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L			
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.8			=	7.3	12 - SU	0	01/07 - Weekly	GR - Grab
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU			
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	11.0	=	12.0	26 - lb/d			=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	375.0 MO AVG	<=	563.0 MX WK AV	26 - lb/d			<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L			
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample								=	298.0	=	314.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L			
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	62.5	=	67.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L			
					Value NODI															
00600	Nitrogen, total [as N]	G - Raw Sewage Influent	0	--	Sample								=	75.2	=	80.4	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L			
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample								=	0.28	=	0.36	19 - mg/L	0	01/07 - Weekly	24 - 24 Hour Composite
					Permit Req.								<=	20.0 MO AVG	<=	30.0 DAILY MX	19 - mg/L			
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	4.59	=	5.31	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L			

					Value NODI																
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample									=	6.28	=	6.8	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.										Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L			
					Value NODI																
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.4537	=	0.7003	03 - MGD									0	99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD											
					Value NODI																
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	0.5287	=	0.7971	03 - MGD									0	01/07 - Weekly	CA - Calculated
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD											
					Value NODI																
51040	E. coli	1 - Effluent Gross	0	--	Sample									=	2.3	=	6.0	13 - #/100mL	0	01/07 - Weekly	GR - Grab
					Permit Req.									<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL			
					Value NODI																
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample									=	98.4			23 - %	0	01/30 - Monthly	CA - Calculated
					Permit Req.									>=	85.0 MO AV MN			23 - %			
					Value NODI																
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample									=	99.0			23 - %	0	01/30 - Monthly	CA - Calculated
					Permit Req.									>=	85.0 MO AV MN			23 - %			
					Value NODI																

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
OHIO_RIVER_COVER_11_25.pdf	pdf	36331.0
OHIO_RIVER_BYPASS_REPORT_11_25.pdf	pdf	112130.0

Report Last Saved By

Louisville and Jefferson County MSD

User:

ALEX.SMITHER@LOUISVILLEMSD.ORG

Name:

Charles Smither

E-Mail:

alex.smither@louisvillemSD.org

Date/Time:

2025-12-22 12:20 (Time Zone: -05:00)

Report Last Signed By

User:

ALEX.SMITHER@LOUISVILLEMSD.ORG

Name:

Charles Smither

E-Mail:

alex.smither@louisvillemSD.org

Date/Time:

2025-12-22 12:20 (Time Zone: -05:00)



**IMSAST0004
Overflow Report**

11/1/2025 12:00:00 AM to 12/1/2025 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center		Recieving Steam of Discharge		Region					
KY0106143	WQTCOR	OHIO RIVER WQTC		OHIO RIVER		OLDHAM					
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSOR-PBPT	1211 PEBBLE PT					LITTLE HUCKLEBERRY CREEK		GROUND		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW:DRY WEATHER DISCHARGE	4026024		11/21/2025 9:02:00 AM	PARKER	PARKER	EXTERNAL INFLUENCE	11/21/2025 12:00:00 AM	POWER OUTAGE (LG&E)	UNAUTHORIZED DISCHARGE-WATERS	11/21/25 02:09 PM	

Discharge Reporting:

Discharge Amount:	800 GAL
Cause:	POWER FAILURE, GENERATORS PLACED BUT PUMPS FAILED TO START.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE VISIBLE AROUND PUMPED DISCHARGE SITE.
Repair:	PLACED GENERATOR.
Public Notification:	PUBLIC NOTICE POSTED TO WEBSITE.

Notifications:

11/21/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/21/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
11/1/2025 12:00:00 AM to 12/1/2025 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0106143	WQTCOR	OHIO RIVER WQTC			OHIO RIVER		OLDHAM				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Main	SSPSOR-MYLN	13410 LONGWOOD LN					POND CREEK		GROUND		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	4015987		11/4/2025 9:45:00 AM	PARKER	PARKER	REPAIRED - ISSUE RESOLVED	11/4/2025 12:00:00 AM	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	11/04/25 10:00 AM	

Discharge Reporting:

Discharge Amount:	330 GAL
Cause:	STRUCTURAL FAILURE (FORCE MAIN BREAK).
Clean Up:	MSD CONTRACTOR CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND IN THE STREAM.
Repair:	REPAIRED THE FORCE MAIN - ON GOING REPAIRS.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/4/25 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/4/25 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION