



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

April 21, 2026

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Bullitt Hills STP, KPDES No: KY0034801  
Discharge Monitoring Report for March 2026.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for Bullitt Hills STP, for the month of March 2026.

There were no exceedances, or bypasses.

Please see attached bypass report.

If you have any questions concerning the attached DMR's, please contact me at (502) 540-6000.

Sincerely,

Curt Otto  
Process Supervisor

CO/BH 3/26.

Cc: V. Teague, B. Tinnel



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments****Attachments**

Name	Type	Size
BullittHillsCL3_26.pdf	pdf	33611.0
All_other_service_area_Discharge_report_March_2026.pdf	pdf	117527.0

**Report Last Saved By****Louisville and Jefferson County MSD**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
 Name: Curt Otto  
 E-Mail: curt.otto@louisvillemSD.org  
 Date/Time: 2026-04-24 08:23 (Time Zone: -04:00)

**Report Last Signed By**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
 Name: Curt Otto  
 E-Mail: curt.otto@louisvillemSD.org  
 Date/Time: 2026-04-24 08:23 (Time Zone: -04:00)



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0098540	WQTCCC	CEDAR CREEK WQTC	CEDAR CREEK	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Manhole	103776	8900 CEDAR CREEK RD	CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	4076631		3/31/2026 11:23:00 AM	YARBROUGH	YARBROUGH	REPAIRED - ISSUE RESOLVED	3/31/2026 12:00:00 AM	ROOTS	UNAUTHORIZED DISCHARGE- WATERS	03/31/26 03:37 AM	MAIN

**Discharge Reporting:**

Discharge Amount:	40 GAL
Cause:	ROOTS IN MAIN SEWER   GREASE IN MAIN SEWER.
Clean Up:	DISCLN #4076632.
Control Zone:	MSD PERSONNEL ADVISED THE CUSTOMER TO AVOID CONTACT WITH SEWAGE.
Impact:	DISCHARGE TO STORM CHANNEL NEAR MANHOLE.
Repair:	FLUSHED SANITARY MAIN TO CLEAR OBSTRUCTION 4076637.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/31/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--



**IMSAST0004**  
**Overflow Report**  
**3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0098540	WQTCCC	CEDAR CREEK WQTC	CEDAR CREEK	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Manhole	103777	9040 BLACK POWDER LN	CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	4076630		3/31/2026 11:22:00 AM	YARBROUGH	YARBROUGH	REPAIRED - ISSUE RESOLVED	3/31/2026 12:00:00 AM	ROOTS	UNAUTHORIZED DISCHARGE- WATERS	03/31/26 03:40 AM	MAIN

**Discharge Reporting:**

Discharge Amount:	50 GAL
Cause:	ROOTS IN MAIN SEWER   GREASE IN MAIN SEWER.
Clean Up:	DISCLN 4076632.
Control Zone:	MSD PERSONNEL ADVISED THE CUSTOMER TO AVOID CONTACT WITH SEWAGE.
Impact:	SANITARY DISCHARGE TO STORM CHANNEL.
Repair:	MANHOLE WORK ORDER HAS BEEN CREATED FOR ROOT INTRUSION MHRP 4076633.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/31/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--



**IMSAST0004**  
**Overflow Report**  
**3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC	OHIO RIVER	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Main	70160A-AG	5806 BRANDYWYNE CT	FERN CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4068303		3/16/2026 3:54:00 PM	SOSA RODRIGUEZ	SOSA RODRIGUEZ	REPAIRED - ISSUE RESOLVED	3/16/2026 12:00:00 AM	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE-WATERS	03/16/26 09:37 PM	

**Discharge Reporting:**

Discharge Amount:	100 GAL
Cause:	STRUCTURAL FAILURE (FORCE MAIN BREAK).
Clean Up:	MSD CONTRACTOR CLEANED AND SANITIZED THE IMPACTED AREA DISCLN 4068326.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE VISIBLE AROUND DISCHARGE SITE.
Repair:	REPAIRED THE MAIN SEWER; WORK ORDER.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/17/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---



**IMSAST0004**  
**Overflow Report**  
**3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034169	WQTCH2	HILLVIEW #2 WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSH2-WTRI	165 OCTAGON AVE		

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4064392		3/5/2026 4:51:00 PM	MILES	MILES	QUEUED FOR INVESTIGATION / REPAIR	3/5/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	03/06/26 01:05 PM	

**Discharge Reporting:**

Discharge Amount:	51,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	DISCLN 4064514.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	WATER FLOWING TO STREAM.
Repair:	NONE, LACK OF CAPACITY.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/6/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/6/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	WQTCWB	WILLABROOK WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4064270		3/5/2026 2:28:00 PM	BROADEN	MILES	DOCUMENTED	3/16/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	03/06/26 08:55 AM	

**Discharge Reporting:**

Discharge Amount:	48,400 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NONE OBSERVED BY MSD PERSONNEL.
Repair:	INVESTIGATION INDICATED THAT ADDITIONAL REPAIRS WERE NOT REQUIRED BY MSD.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

3/6/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/6/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	WQTCWB	WILLABROOK WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4064852		3/7/2026 2:01:00 PM	MILES	MILES	DOCUMENTED	3/16/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	03/08/26 10:00 AM	

**Discharge Reporting:**

Discharge Amount:	47,300 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPES DISCHARGE UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PERMANENT SIGNS PLACED.
Impact:	NONE OBSERVED.
Repair:	NO ACTION TAKEN, LACK OF CAPACITY.
Public Notification:	SIGNS IN THE IMPACTED AREA.

**Notifications:**

3/8/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/8/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004  
Overflow Report  
3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	WQTCWB	WILLABROOK WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4068138		3/16/2026 2:44:00 AM	BROADEN	BROADEN	DOCUMENTED	3/16/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	03/18/26 08:31 AM	

**Discharge Reporting:**

Discharge Amount:	16,800 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPES DISCHARGE UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PERMANENT SIGNS PLACED.
Impact:	NONE OBSERVED.
Repair:	NO ACTION TAKEN, LACK OF CAPACITY.
Public Notification:	SIGNS IN THE IMPACTED AREA.

**Notifications:**

3/16/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/16/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034801	WQTCBH	BULLITT HILLS WQTC	TANYARD BRANCH	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTCBH	233 MAYFLOWER RD	TANYARD BRANCH	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4064855		3/7/2026 2:35:00 PM	REED	REED	DOCUMENTED	3/7/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/08/26 05:50 AM	

**Discharge Reporting:**

Discharge Amount:	137,250 GAL
Cause:	BYPASS AT WASTEWATER TREATMENT PLANT.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	PLANT FLOW SUBSIDED.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

**Notifications:**

3/8/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/8/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC	OHIO RIVER	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTC DG	11621 LOWER RIVER RD	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4065111		3/9/2026 9:55:00 AM	REED	REED	REPAIRED - ISSUE RESOLVED	3/9/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/09/26 10:00 AM	

**Discharge Reporting:**

Discharge Amount:	2,600 GAL
Cause:	BYPASS AT WASTEWATER TREATMENT PLANT.
Clean Up:	MSD CONTRACTOR CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SOLIDS FOUND ON THE GROUND.
Repair:	CLOSED VALVE.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

**Notifications:**

3/9/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
----------------	--------	---



**IMSAST0004  
Overflow Report  
3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034151	WQTCH1	HILLVIEW #1 WQTC	TANYARD BRANCH	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTCH1	253 LEES LN	TANYARD BRANCH	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4064861		3/7/2026 2:55:00 PM	REED	REED	DOCUMENTED	3/7/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/07/26 07:10 PM	

**Discharge Reporting:**

Discharge Amount:	360,000 GAL
Cause:	BYPASS AT WASTEWATER TREATMENT PLANT.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PERMANENT SIGNS SUPPLEMENTED WITH TEMPORARY SIGNS AND CONES.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE, WETWELL, GROUND, AND STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

**Notifications:**

3/8/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
----------------	--------	---



**IMSAST0004**  
**Overflow Report**  
**3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Discharge</b>	<b>Region</b>
KY0034177	WQTCH3	HILLVIEW #3 WQTC	BROOKS RUN	BULLITT

<b>Facility Type</b>	<b>Facility ID</b>	<b>Facility Address</b>	<b>Receiving Stream</b>	<b>Discharge To</b>
Sewer Treatment Plant	WQTCH3	126 WESTERN RD	BROOKS RUN	STREAM

<b>Activity Code / Description</b>	<b>WO #</b>	<b>Ref #</b>	<b>Initiated on</b>	<b>Initiated By</b>	<b>Assigned To</b>	<b>Dish Status</b>	<b>Event Date</b>	<b>Problem Desc</b>	<b>Result</b>	<b>Completed</b>	<b>Condition</b>
DISREV:RAIN EVENT DISCHARGE	4064864		3/7/2026 3:00:00 PM	REED	REED	DOCUMENTED	3/7/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/07/26 07:45 PM	

**Discharge Reporting:**

Discharge Amount:	2,850 GAL
Cause:	BYPASS AT WASTEWATER TREATMENT PLANT.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

**Notifications:**

3/8/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
----------------	--------	---



**IMSAST0004  
Overflow Report  
3/1/2026 12:00:00 AM to 3/31/2026 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	WQTCPV	PIONEER VILLAGE #1 WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTCPV	815 JOHN HARPER HWY	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4064869		3/7/2026 3:20:00 PM	REED	REED	DOCUMENTED	3/7/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	03/08/26 06:00 AM	

**Discharge Reporting:**

Discharge Amount:	44,000 GAL
Cause:	BYPASS AT WASTEWATER TREATMENT PLANT.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE AND ON GROUND.
Repair:	PLANT FLOW SUBSIDED.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

**Notifications:**

3/8/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
3/8/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION