



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

March 18, 2026

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hillview 3 STP, KPDES No: KY0034177
Discharge Monitoring Report for February 2026.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview Plant #3 WQTC, for the month of February 2026.

There were no bypasses or overflows.

There were two exceedances on max daily TSS with a result of 33 mg/l and permit limit of 30 mg/l and max monthly TSS with a result of 81 mg/l and permit limit of 45 mg/l. Due to heavy rain during the last week of sampling causing us to have to shut down the plant and not being able to get enough air back on it before the deadline to sample.

If you have any questions concerning the attached DMR's, please contact me at (502) 919-5794

Sincerely,

Kevin Thompson
Process Supervisor

SR/HV3 02/26.

Cc: V. Teague, B. Tinnel

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments**Attachments**

Name	Type	Size
202602_Hillview3_coverletter.pdf	pdf	37050.0

Report Last Saved By**Louisville and Jefferson County MSD**

User: kevin.thompson@louisvillemmsd.org
 Name: Kevin Thompson
 E-Mail: kevin.thompson@louisvillemmsd.org
 Date/Time: 2026-03-20 07:55 (Time Zone: -04:00)

Report Last Signed By

User: kevin.thompson@louisvillemmsd.org
 Name: Kevin Thompson
 E-Mail: kevin.thompson@louisvillemmsd.org
 Date/Time: 2026-03-20 07:55 (Time Zone: -04:00)