



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

June 24, 2026

Crystal Dennis
300 Sower Boulevard, 3rd Floor
Frankfort, KY 40601

RE: Hillview Plant #3 STP, KPDES No. KY0034177
Discharge Monitoring Report – May 2026

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for Hillview Plant #3 STP for the month of May 2026.

There were no exceedances, bypasses, or overflows during the reporting period.

If you have any questions regarding the attached DMRs, please contact me on (502) 540-6000.

Sincerely,

A handwritten signature in black ink, appearing to read 'Jesse Howard'. The signature is fluid and cursive, with a large, looping 'J' and 'H'.

Jesse Howard
Process Supervisor

JH/HV3 5/26

cc: V. Teague, B. Tinnel

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #:
Major:

KY0034177
No

Permittee:
Permittee Address:

Louisville and Jefferson County MSD
700 W Liberty St
Louisville, KY 40203

Facility:
Facility Location:

BCSD HILLVIEW #3
12325 WESTERN RD
HILLVIEW, KY 40129

Permitted Feature:

001
External Outfall

Discharge:

001-1
Domestic Wastewater

Report Dates & Status

Monitoring Period:

From 05/01/26 to 05/31/26

DMR Due Date:

06/28/26

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:
Last Name:

James
Parrott

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration								# of Ex.	Frequency of Analysis	Sample Type
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.5					19 - mg/L	0	01/07 - Weekly	GR - Grab	
					Permit Req.						>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - Grab	
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.1			=	8.0	12 - SU	0	01/07 - Weekly	GR - Grab	
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 DAILY MX	12 - SU		01/07 - Weekly	GR - Grab	
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								=	5.0	=	8.0	19 - mg/L	0	01/07 - Weekly	CP - Composite	
					Permit Req.								<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	CP - Composite	
					Value NODI																
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	30.0	=	35.5	19 - mg/L	0	01/07 - Weekly	CP - Composite	
					Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L		01/07 - Weekly	CP - Composite	
					Value NODI																
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample								=	0.54	=	1.4	19 - mg/L	0	01/07 - Weekly	CP - Composite	
					Permit Req.								<=	4.0 MO AVG	<=	6.0 DAILY MX	19 - mg/L		01/07 - Weekly	CP - Composite	
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	=	2.78	=	3.41	26 - lb/d			=	3.05	=	4.55	19 - mg/L	0	01/07 - Weekly	CP - Composite	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	26 - lb/d				Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L		01/07 - Weekly	CP - Composite	
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample														01/30 - Monthly	CA - Calculated	
					Permit Req.	<=	3.71 ROLL AVG			26 - lb/d											
					Value NODI		9 - Conditional Monitoring - Not Required This Period														
					Sample	=	0.1687	=	0.5241	03 - MGD									99/99 - Continuous	RC - Recorder (auto)	

50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							0	01/07 - Weekly	IN - Instantaneous	
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	4.3	=	14.0	13 - #/100mL	0	01/07 - Weekly	GR - Grab
					Permit Req.							<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL	01/07 - Weekly		GR - Grab	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample								=	4.0	=	6.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.							<=	15.0 MO AVG	<=	22.5 MX WK AV	19 - mg/L	01/07 - Weekly		CP - Composite	
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
CLHV3May26.pdf	pdf	32710.0
HILLVIEW3LIMSPCSPREADSHEET011323052026.xls	xls	190976.0

Report Last Saved By

Louisville and Jefferson County MSD

User: JESSE.HOWARD@LOUISVILLEMSD.ORG

Name: Jesse Howard

E-Mail: jesse.howard@louisvillemSD.org

Date/Time: 2026-06-25 11:16 (Time Zone: -04:00)

Report Last Signed By

User: JESSE.HOWARD@LOUISVILLEMSD.ORG

Name: Jesse Howard

E-Mail: jesse.howard@louisvillemSD.org

Date/Time: 2026-06-25 11:42 (Time Zone: -04:00)

Month

	A	C	G	I	K	L	O	P	Q	R	V	Y	Z	AN	AP	AR	AT	BD
1	"Ctrl+Shift+E" to export BCSD Hillview #3				May-26					May								
2		Plant f	Effl.	Effl.	Effl.		Effl.	ECOLI	Effl.	Effl.	Eff.	Eff.		Effluent	Effluent	Eff	Eff.	
3	DATE	Flow	CBOD	TSS	NH3	<	T-Phos.	MPN	pH	DO	TN	Total Res. Cl2	<	CBOD	TSS	NH3	Phos.	<
4		(MGD)	(mg/L)	(mg/L)	(mg/L)	>	(mg/L)	(Colonies)		(mg/L)	(mg/L)	(mg/L)	>	pounds	pounds	pounds	pounds	>
5	5/1/2026	0.154				<							<					<
6	5/2/2026	0.148				<							<					<
7	5/3/2026	0.141				<							<					<
8	5/4/2026	0.113	2	4	1.4	<	3.32	1.00	8	8	26.20		<	1.879236	3.758471	1.315465	3.119531	<
9	5/5/2026	0.112				<							<					<
10	5/6/2026	0.194				<							<					<
11	5/7/2026	0.144				<							<					<
12	5/8/2026	0.130				<							<					<
13	5/9/2026	0.125				<							<					<
14	5/10/2026	0.117				<							<					<
15	5/11/2026	0.102	6	4	0.25	<	3.81	6.00	7.8	8.2	35.50		<	5.1287	3.419133	0.213696	3.256724	<
16	5/12/2026	0.099				<							<					<
17	5/13/2026	0.103				<							<					<
18	5/14/2026	0.105				<							<					<
19	5/15/2026	0.104				<							<					<
20	5/16/2026	0.115				<							<					<
21	5/17/2026	0.106				<							<					<
22	5/18/2026	0.090	3	3	0.25	<	4.55	14.00	7.1	7.5	34.60		<	2.251575	2.251575	0.187631	3.414888	<
23	5/19/2026	0.098				<							<					<
24	5/20/2026	0.130				<							<					<
25	5/21/2026	0.135				<							<					<
26	5/22/2026	0.229				<							<					<
27	5/23/2026	0.524				<							<					<
28	5/24/2026	0.329				<							<					<
29	5/25/2026	0.248				<							<					<
30	5/26/2026	0.391				<							<					<
31	5/27/2026	0.314	3	8	0.25	<	0.51	4.00	7.4	7.6	23.50		<	7.86286	20.96763	0.655238	1.336686	<
32	5/28/2026	0.188				<							<					<
33	5/29/2026	0.158				<							<					<
34	5/30/2026	0.147				<							<					<
35	5/31/2026	0.139				<							<					<
36	TOTAL	5.231												17.12	30.40	2	11.13	
37	AVERAGE*	0.169	4	5	0.54	<	3.05	4.28139	7.6	7.8	29.95	0.000	<	4.28	7.60	0.59	2.78	<
38	MINIMUM	0.090	2	3	0.25	<	0.51	1	7.1	7.5	23.50	0.000	<	2	2	0	1.3	<
39	MAXIMUM	0.524	6	8	1.40	<	4.55	14	8.0	8.2	35.50	0.000	<	8	21	1	3.4	<
40	*For E. Coli: Calculation is for Geometric Mean (not Aver																	
41	Max.Wk Avg	0.318	0	0	2.0		4.6	0			36			8	21	1	3.4	
42	Exceed.	0	0	0	0		3	0	0	0				0	0	0	0	
43	MxWkAvg																	
43	Exceed		0	0	0		0	0	0					0	0	0	0	
44	Mo Avg																	
44	Exceed		0	0	0		0	0	0	0				0	0	0	0	
45	Total KLBS Treated																	