



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

April 21, 2026

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Prologis STP, KPDES No: KY0103900  
Discharge Monitoring Report March 2026.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for Prologis WQTC, for the month of March 2026.

There were no bypasses, overflows.

There was one exceedance at the plant.  
Resulting in a 6.2 mg/L Do read with a minimum permit read of 7.0 mg/L.

If you have any questions concerning the attached DMR's, please contact me at (502) 540-6000.

Sincerely,

Curt Otto  
Process Supervisor

SR/Prologis 3/26.

Cc: V. Teague, B. Tinnel

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

<b>Permit</b>		<b>Permit #:</b> KY0103900		<b>Permittee:</b> Louisville and Jefferson County MSD		<b>Facility:</b> BCSD HILLVIEW STP	
<b>Major:</b> No		<b>Permittee Address:</b> 700 W Liberty St Louisville, KY 40203		<b>Facility Location:</b> 285 BROOKS WAY BROOKS, KY 40109			
<b>Permitted Feature:</b> 001 External Outfall		<b>Discharge:</b> 001-1 Domestic Wastewater from a Publicly Owned Treatment Works					
<b>Report Dates &amp; Status</b>							
<b>Monitoring Period:</b> From 03/01/26 to 03/31/26		<b>DMR Due Date:</b> 04/28/26		<b>Status:</b> NetDMR Validated			
<b>Considerations for Form Completion</b>							
Total Nitrogen is the summation of the analytical results for Total Nitrates, Total Nitrites, and Total Kjeldahl Nitrogen							
<b>Principal Executive Officer</b>							
<b>First Name:</b> James A		<b>Title:</b> Executive Director		<b>Telephone:</b> 502-540-6533			
<b>Last Name:</b> Parrot							
<b>No Data Indicator (NODI)</b>							
<b>Form NODI:</b> --							

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
X 00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	6.2					19 - mg/L	1	01/07 - Weekly	GR - Grab	
					Permit Req.					>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - Grab	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.1			=	7.1	12 - SU	0	01/07 - Weekly	GR - Grab	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/07 - Weekly	GR - Grab	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1.2	=	1.3	26 - lb/d		=	3.5	=	5.0	19 - mg/L	0	01/07 - Weekly	CP - Composite	
					Permit Req.	<=	37.53 MO AVG	<=	56.295 MX WK AV	26 - lb/d		<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite	
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	116.0	=	298.0	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req.												19 - mg/L	01/07 - Weekly	24 - 24 Hour Composite	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	14.25	=	23.7	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req.													19 - mg/L	01/07 - Weekly	24 - 24 Hour Composite
					Value NODI															
00600	Nitrogen, total [as N]	G - Raw Sewage Influent	0	--	Sample						=	45.78	=	62.6	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req.													19 - mg/L	01/07 - Weekly	24 - 24 Hour Composite
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample						=	0.35	=	0.7	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req.						<=	8.0 MO AVG	<=	12.0 DAILY MX	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite		
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	2	--	Sample						=	0.71	=	1.16	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req.						<=	1.0 MO AVG					19 - mg/L	01/07 - Weekly	24 - 24 Hour Composite	
					Value NODI															
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample						=	4.72	=	6.7	19 - mg/L	0	01/07 - Weekly	CP - Composite		
					Permit Req.													19 - mg/L	01/07 - Weekly	24 - 24 Hour Composite
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.0392	=	0.09	03 - MGD						0	99/99 - Continuous	RC - Recorder (auto)		
					Permit Req.													99/99 - Continuous	RE - Record (manual)	

