



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

February 20th, 2026

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Willabrook STP, KPDES No: KY0094307
Discharge Monitoring Report for January 2026.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Willabrook WQTC, for the month of January 2026.

There were no overflows or bypasses.

There was one exceedance for TSS weekly average with a result of 47 mg/L with a limit of 45mg/L.

If you have any questions concerning the attached DMR's, please contact me at (502) 919-5794.

Sincerely,

Scott Reed
Process Supervisor

SR/WB 1/26.

Cc: V. Teague, B. Tinnel

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments**Attachments**

Name	Type	Size
WB_1_26_CoverLetter.pdf	pdf	36839.0

Report Last Saved By**Louisville and Jefferson County MSD**

User: kevin.thompson@louisvillemd.org
 Name: Kevin Thompson
 E-Mail: kevin.thompson@louisvillemd.org
 Date/Time: 2026-02-23 09:58 (Time Zone: -05:00)

Report Last Signed By

User: REED0325
 Name: Scott Reed
 E-Mail: reeds@louisvillemd.org
 Date/Time: 2026-02-23 11:51 (Time Zone: -05:00)