



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

July 20, 2026

Crystal Dennis
300 Sower Boulevard, 3rd Floor
Frankfort, KY 40601

RE: Cedar Creek WQTC, KPDES No. KY0098540
Discharge Monitoring Report – June 2026

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and Monthly Operator Report (MOR) for Cedar Creek WQTC for the month of June 2026.

There were no bypasses or permit exceedances during the reporting period.

Please see attached overflow report.

If you have any questions regarding the attached DMRs, please contact me at (502) 540-6000.

Sincerely,

A handwritten signature in black ink, appearing to read 'Curt Otto', written over a light gray circular background.

Curt Otto
Process Supervisor

CO/Cedar Creek 6/26

Enclosures

cc: V. Graves, B. Tinnell

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the [NPDES eReporting Help Desk](#) for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #:
Major:

KY0098540
Yes

Permittee:
Permittee Address:

Cedar Creek WQTC MSD
700 W Liberty St
Louisville, KY 40203

Facility:
Facility Location:

CEDAR CREEK WQTC MSD
8405 CEDAR CREEK RD
LOUISVILLE, KY 40291

Permitted Feature:

001
External Outfall

Discharge:

001-1
MUNICIPAL DISCHARGE

Report Dates & Status

Monitoring Period:

From 06/01/26 to 06/30/26

DMR Due Date:

07/28/26

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:
Last Name:

James
Parrott

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	8.2					19 - mg/L	0	01/07 - Weekly	GR - Grab
					Permit Req.						>=	7.0 INST MIN					19 - mg/L			
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.7			=	8.0	12 - SU	0	01/07 - Weekly	GR - Grab
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU			
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	144.0	=	188.0	26 - lb/d			=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	1877.0 MO AVG	<=	2815.0 MX WK AV	26 - lb/d			<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L			
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample								=	115.0	=	198.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L			
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample								=	8.0	=	9.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.									Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L			
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	52.0	=	157.0	26 - lb/d			=	0.9	=	2.5	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	250.0 MO AVG	<=	376.0 MX WK AV	26 - lb/d			<=	4.0 MO AVG	<=	6.0 MX WK AV	19 - mg/L			
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample								=	0.44	=	0.8	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.								<=	1.0 MO AVG	<=	1.5 MX WK AV	19 - mg/L			
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	6.797	=	10.488	03 - MGD								0	99/99 - Continuous	CN - Continuous
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD										
					Value NODI															
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	7.519	=	11.132	03 - MGD								0	99/99 - Continuous	CN - Continuous
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD										
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	2.0	=	6.0	13 - #/100mL	0	01/07 - Weekly	GR - Grab
					Permit Req.								<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL			

					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	180.0	=	248.0	26 - lb/d		=	4.0	=	7.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.	<=	626.0 MO AVG	<=	939.0 MX WK AV	26 - lb/d		<=	10.0 MO AVG	<=	15.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample							=	86.0	=	118.0	19 - mg/L	0	01/07 - Weekly	CP - Composite
					Permit Req.								Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample					=	95.0					23 - %	0	01/30 - Monthly	CA - Calculated
					Permit Req.					>=	85.0 MO AV MN					23 - %		01/30 - Monthly	CA - Calculated
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample					=	97.0					23 - %	0	01/30 - Monthly	CA - Calculated
					Permit Req.					>=	85.0 MO AV MN					23 - %		01/30 - Monthly	CA - Calculated
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
All_other_service_area_Discharge_report_June_2026.pdf	pdf	184363.0
CCMOR062026.pdf	pdf	74820.0
CedarCreekCLJune26.pdf	pdf	34624.0

Report Last Saved By

Cedar Creek WQTC MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG

Name: Curt Otto

E-Mail: curt.otto@louisvillemSD.org

Date/Time: 2026-07-22 10:00 (Time Zone: -04:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG

Name: Curt Otto

E-Mail: curt.otto@louisvillemSD.org

Date/Time: 2026-07-22 10:03 (Time Zone: -04:00)

NAME OF TREATMENT PLANT CEDAR CREEK WTP COUNTY JEFFERSON MONTH OF: June 2026
 KPDES PERMIT NUMBER KY0098540 PLANT CAPACITY 7.5 MGD RECEIVING STREAM CEDAR CREEK

DATE	TOTAL FLOW (MILLION GALLONS)	RAW SEWAGE		pH		SETTLEABLE SOLIDS (mg/L)			DISSOLVED OXYGEN (mg/L)			SUSPENDED SOLIDS (mg/L)			5 DAY CBOD (mg/L)			ACTIVATED SLUDGE			AERATION BASIN					SLUDGE HANDLING						FINAL		Total Phosphorus	Total Nitrogen	TOTAL FLOW INF. (MILLION GALLONS)	
		GRIT REMOVED (CUBIC FEET)	SCREENINGS (CUBIC FEET)	RAW	FINAL	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	STREAM ABOVE	FINAL EFFLUENT	STREAM BELOW	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RETURN		WASTED	DISSOLVED OXYGEN (mg/L)	MLSS (mg/L) X 1000	MLVSS (mg/L) X 1000	SETTLED SLUDGE VOLUME		RAW			HAULED			WITHDRAWN GALLONS X 1000	NH3-N (mg/L)				ECOLI
																		GAL/DAY MGD	MLSS					GAL/DAY	30 MIN.	60 MIN.	GALLONS X 1000	% DRY SOLIDS	% VOLATILE SOLIDS	% DRY SOLIDS	% VOLATILE SOLIDS						
1	4.76			7.3														4.53	5020	125000	1.4	3060	2700	500								138600					5.353344
2	4.57			7.4	7.7					8.6		47		3	78		3	3.78	5620	150000	4.7	3120	2700	480								132300	0.25	6	0.357	6.62	5.091821
3	4.34			7.6														3.25	6320	150000	4.9	3080	2650	470								126000					5.610793
4	2.90			7.5														3.26	5360	100000	4.6	2360	2080	350								132000					5.077468
5	3.53			7.4														3.04	4820	125000	4.4	2310	2110	350								145200					5.128633
6	4.10																	3.16		100000	5.5			340								0				4.577169	
7	4.07																	3.15		100000	5			360								0				4.567512	
8	4.10			7.3														3.13	4810	125000	2.8	2540	2120	430								119700					4.525949
9	6.75			7.6	8.0					8.2		186		3	118		3	2.87	5800	100000	4.3	2440	2170	400								144900	0.28	1	0.813	9.02	7.053243
10	6.20			7.4														3	7150	100000	4.3	2480	2170	400								100800					6.453361
11	4.89			7.3														2.08	6030	125000	3.7	2410	2220	410								94500					5.248189
12	5.32			7.4														2.33	7760	125000	3.6	2340	2100	340								75600					5.811116
13	4.87																	3.18		100000	3			300								0				5.315981	
14	4.80																	3.23		100000	3.3			310								0				5.1283	
15	4.38			7.4														3	5880	125000	2.9	2680	2300	450								132300					4.930469
16	4.24			7.5	7.7					8.4		198		3	118		7	2.18	5380	125000	3.7	2610	2330	450								144900	0.75	1	0.15	8.42	4.844162
17	3.92			7.2														2.04	7470	100000	2.9	2330	2030	390								138600					5.311945
18	9.24			7.4														4.01	8400	75000	3.8	1610	1480	200								126000					12.40321
19	9.32																	4.67		100000	4.1			350								119700					9.582311
20	6.97																	3.98		125000	3.4			400								0				7.37642	
21	5.83																	4.65		125000	2.4			450								0				6.308114	
22	9.94			7.2														4.5	7400	150000	2.6	3140	2740	450								0				10.19669	
23	7.53			7.2	7.7					8.4		28		3	28		3	4.16	6020	150000	4.3	2870	2540	400								132000	2.50	1	0.441	6.39	7.894019
24	6.29			7.5														2.9	6890	125000	1	2480	2210	340								126000					6.773714
25	5.61			7.3														2.07	5390	100000	4.3	2140	1910	330								113400					6.020165
26	9.06			7.5														2.15	6110	75000	3.5	1940	1730	300								132300					9.809503
27	19.91																	4.24		100000				300								0				22.26773	
28	15.07																	5		100000	3.9			200								0				14.96305	
29	11.38			7.5														4.05	4000	100000	4.5	1100	970	260								151200					11.69222
30	10.02			7.6														3.81	3840	50000	5.3	1120	940	150								119700					10.26297
31																																					
Tot.	203.90																	101.4														2645700					225.579571
Avg.	6.80			7.4	7.8					8.4		115		3	86		4	3.38	5975	111667	3.728	2389	2105	362								88190	0.95	2	0.44	7.613	7.519319033

RESIDENTIAL
COMMERCIAL
INDUSTRIAL

INDUSTRIAL WASTE POPULATION EQUIVALENT

64730
FLOW

28509
CBOD

30974
TSS

Chris Coomer
OPERATOR

18291
CERT. NO.

TOTAL NUMBER OF SEWER CONNECTIONS

SEWER CONNECTIONS 0 X 4 = 0 SEWERED POPULATION

502-540-6000

PLANT TELEPHONE



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0098540	WQTCCC	CEDAR CREEK WQTC			CEDAR CREEK		JEFFERSON				
Facility Type	Facility ID	Facility Address				Recieving Stream		Discharge To			
Sewer Manhole	113002	9740 WATERBROOK CT				DURBIN BRANCH		GROUND			
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW:DRY WEATHER DISCHARGE	4119640		6/21/2026 1:31:00 PM	MILES	MILES	REPAIRED - ISSUE RESOLVED	6/21/2026 12:00:00 AM	GREASE BLOCKAGE	UNAUTHORIZED DISCHARGE-WATERS	06/21/26 07:16 PM	

Discharge Reporting:

Discharge Amount:	8,625 GAL
Cause:	GREASE IN MAIN SEWER.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA DISCLN 4119671.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/WATER DISCHARGING FROM MANHOLE.
Repair:	FLUSHED/VACTORED THE OBSTRUCTION / DEBRIS FROM THE SEWER.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/22/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/22/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTCDG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Manhole	29948	6810 SANDSTONE BLVD					FERN CREEK		GROUND		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122101		6/27/2026 12:23:00 PM	MIDASSYS	TAYLOR	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	06/27/26 03:42 PM	

Discharge Reporting:

Discharge Amount:	3,600 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	DISCLN 4122135.
Control Zone:	BARRICADES, CONES AND TAPE PLACED AROUND SITE.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AT SITE. GREASE IN MANHOLE.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PERMANENT SIGNS INSTALLED AT SITE AND DOOR HANGERS PLACED AROUND NEIGHBORHOOD.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Receiving Stream of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address				Receiving Stream			Discharge To		
Sewer Manhole	57353	1103 FARMAN CT				FISHPOOL CREEK			CATCH BASIN		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122138		6/27/2026 3:49:00 PM	MIDASSYS	MARSH JR	QUEUED FOR INVESTIGATION / REPAIR	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	06/27/26 03:51 PM	

Discharge Reporting:

Discharge Amount:	22,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	DISCLN 4122141.
Control Zone:	BARRICADES, CONES AND TAPE PLACED AROUND SITE.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AT SITE. GREASE IN MANHOLE.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PERMANENT SIGNS INSTALLED AT SITE AND DOOR HANGERS PLACED AROUND NEIGHBORHOOD.

Notifications:

6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Manhole	64054	7014 JOHN PAUL LN					PENNSYLVANIA RUN		GROUND		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122088		6/27/2026 2:20:00 PM	MIDASSYS	TAYLOR	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	06/30/26 02:21 PM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	DISCLN 4122675.
Control Zone:	BARRICADES, CONES AND TAPE PLACED AROUND SITE.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AT SITE. GREASE IN MANHOLE.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PERMANENT SIGNS INSTALLED AT SITE AND DOOR HANGERS PLACED AROUND NEIGHBORHOOD.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC	OHIO RIVER	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Manhole	90380	4739 DIXIE HWY	MILL CREEK	CATCH BASIN

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122030		6/27/2026 8:24:00 AM	MIDASSYS	TAYLOR	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	06/27/26 02:29 PM	

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	DISCLN #4122130.
Control Zone:	BARRICADES, CONES AND TAPE PLACED AROUND SITE.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AT SITE. GREASE IN MANHOLE.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PERMANENT SIGNS INSTALLED AT SITE AND DOOR HANGERS PLACED AROUND NEIGHBORHOOD.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Manhole	93704	8800 ADMIRAL DR					CEDAR CREEK		DITCH		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122085		6/27/2026 11:36:00 AM	MIDASSYS	TAYLOR	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	06/28/26 10:23 AM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	DISCLN 4122193.
Control Zone:	BARRICADES, CONES AND TAPE PLACED AROUND SITE.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AT SITE. GREASE IN MANHOLE.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PERMANENT SIGNS INSTALLED AT SITE AND DOOR HANGERS PLACED AROUND NEIGHBORHOOD.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC	OHIO RIVER	JEFFERSON

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Manhole	93705	8800 ADMIRAL DR	PENNSYLVANIA RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122086		6/27/2026 11:38:00 AM	MIDASSYS	TAYLOR	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/28/26 10:24 AM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	DISCLN 4122194.
Control Zone:	BARRICADES, CONES AND TAPE PLACED AROUND SITE.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AT SITE. GREASE IN MANHOLE.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PERMANENT SIGNS INSTALLED AT SITE AND DOOR HANGERS PLACED AROUND NEIGHBORHOOD.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034801	WQTCBH	BULLITT HILLS WQTC	TANYARD BRANCH	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Lift Station	SSPSBH-PRVL	191 WILMA AVE	TANYARD BRANCH	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122027		6/27/2026 8:10:00 AM	SANTEE	SANTEE	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/27/26 09:00 PM	

Discharge Reporting:

Discharge Amount:	35,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	TEMPORARY SIGNS HAVE BEEN POSTED.
Impact:	NO DEBRIS OBSERVED AT SITE.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	TEMPORARY SIGNS HAVE BEEN POSTED.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSDG-ADMI	8800 ADMIRAL DR					PENNSYLVANIA RUN		STREAM		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122016		6/27/2026 7:30:00 AM	SANTEE	SANTEE	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/27/26 09:15 PM	

Discharge Reporting:

Discharge Amount:	41,250 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEAN AND SANITIZE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AT SITE.
Impact:	SEWAGE DEBRIS AROUND AREA.
Repair:	SCADA INDICATED.
Public Notification:	PLACED TEMPORARY SIGNS AT SITE.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSDG-CIND	9114 CINDERELLA LN					FISHPOOL CREEK		DITCH		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122068		6/27/2026 10:30:00 AM	SANTEE	SANTEE	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/27/26 09:00 PM	

Discharge Reporting:

Discharge Amount:	63,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED.
Repair:	NO REPAIRS REQUIRED.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV

KPDES #	Facility ID	Water Quality Treatment Center			Receiving Stream of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Receiving Stream		Discharge To		
Sewer Lift Station	SSPSDG-LAN1	9317 LANTANA DR					PENNSYLVANIA RUN		DITCH		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4118927		6/18/2026 7:36:00 AM	BROADEN	BROADEN	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/18/26 10:28 AM	

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	MAGNITUDE OF STORM RESULTED IN NO DEBRIS REMAININGNO CLEAN UP PERFORMED.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/WATER DISCHARGING FROM MANHOLE.
Repair:	SITE FOUND DURING RAIN EVENT. RECON WILL BE MONITORED.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/18/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/18/26 1:44 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSDG-LAN1	9317 LANTANA DR					PENNSYLVANIA RUN		DITCH		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122022		6/27/2026 7:55:00 AM	SANTEE	SANTEE	BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	06/27/26 01:00 PM	

Discharge Reporting:

Discharge Amount:	30,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	MAGNITUDE OF STORM RESULTED IN NO DEBRIS REMAININGNO CLEAN UP PERFORMED.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/WATER DISCHARGING FROM MANHOLE.
Repair:	SITE FOUND DURING RAIN EVENT. RECON WILL BE MONITORED.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address				Recieving Stream			Discharge To		
Sewer Lift Station	SSPSH2-WTRI	165 OCTAGON AVE				BROOKS RUN			GROUND		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4119222		6/18/2026 1:40:00 PM	SANTEE	SANTEE	QUEUED FOR INVESTIGATION / REPAIR	6/18/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/18/26 03:30 PM	

Discharge Reporting:

Discharge Amount:	1,650 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	DISCLN 4064514.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	WATER FLOWING TO STREAM.
Repair:	NONE, LACK OF CAPACITY.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/19/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/19/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0106143	WQTCOR	OHIO RIVER WQTC			OHIO RIVER		OLDHAM				
Facility Type	Facility ID	Facility Address				Recieving Stream		Discharge To			
Sewer Lift Station	SSPSOR-CBRD	13301	STHY 329		HARRODS CREEK		GROUND				
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4118692		6/18/2026 5:49:00 AM	BROADEN	BROADEN	DOCUMENTED	6/26/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/18/26 10:34 AM	

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/18/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/18/26 1:44 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0106143	WQTCOR	OHIO RIVER WQTC			OHIO RIVER		OLDHAM				
Facility Type	Facility ID	Facility Address				Recieving Stream			Discharge To		
Sewer Lift Station	SSPSOR-CBRD	13301	STHY 329			HARRODS CREEK			GROUND		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4121922		6/26/2026 10:00:00 PM	SANTEE	SANTEE	DOCUMENTED	6/26/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/27/26 09:00 PM	

Discharge Reporting:

Discharge Amount:	20,700 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/27/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0106143	WQTCOR	OHIO RIVER WQTC			OHIO RIVER		OLDHAM				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSOR-PBPT	1211 PEBBLE PT					LITTLE HUCKLEBERRY CREEK		GROUND		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4121938		6/27/2026 5:30:00 AM	SANTEE	SANTEE	REPAIRED - ISSUE RESOLVED	6/27/2026 12:00:00 AM	ELECTRICAL PROBLEMS AT MSD	UNAUTHORIZED DISCHARGE- WATERS	06/27/26 06:00 AM	

Discharge Reporting:

Discharge Amount:	1,500 GAL
Cause:	MINOR ELECTRICAL ISSUE RELATING TO LEVEL CONTROL DEVICES.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND AROUND MANHOLE.
Repair:	CLEANED ADJUSTED LEVEL DEVICES.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTCDG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD					BROOKS RUN		STREAM		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4112043		6/9/2026 12:51:00 PM	BROADEN	BROADEN	BEYOND APPROVED DESIGN STORM	6/26/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/10/26 02:23 PM	

Discharge Reporting:

Discharge Amount:	1,900 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPES DISCHARGE UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PERMANENT SIGNS PLACED.
Impact:	TELEMETRY.
Repair:	NO ACTION TAKEN, LACK OF CAPACITY.
Public Notification:	SIGNS IN THE IMPACTED AREA.

Notifications:

6/9/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/9/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD					BROOKS RUN		STREAM		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4118695		6/18/2026 6:28:00 AM	BROADEN	BROADEN	BEYOND APPROVED DESIGN STORM	6/26/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	06/18/26 10:09 AM	

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPES DISCHARGE UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PERMANENT SIGNS PLACED.
Impact:	NONE OBSERVED.
Repair:	NO ACTION TAKEN, LACK OF CAPACITY.
Public Notification:	SIGNS IN THE IMPACTED AREA.

Notifications:

6/18/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/18/26 1:44 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD					BROOKS RUN		STREAM		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4119828		6/22/2026 5:30:00 AM	BUTLER	BUTLER	BEYOND APPROVED DESIGN STORM	6/26/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE- WATERS	06/23/26 10:16 AM	

Discharge Reporting:

Discharge Amount:	27,800 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPES DISCHARGE UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NONE OBSERVED BY MSD PERSONNEL.
Repair:	INVESTIGATION INDICATED THAT ADDITIONAL REPAIRS WERE NOT REQUIRED BY MSD.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/22/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/22/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0078956	WQTC DG	DEREK R. GUTHRIE WQTC			OHIO RIVER		JEFFERSON				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Lift Station	SSPSWB-MATL	3955 E BLUE LICK RD					BROOKS RUN		STREAM		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4121934		6/26/2026 11:27:00 PM	SANTEE	SANTEE	BEYOND APPROVED DESIGN STORM	6/26/2026 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	06/29/26 07:21 AM	

Discharge Reporting:

Discharge Amount:	8,800 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPES DISCHARGE UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NONE OBSERVED BY MSD PERSONNEL.
Repair:	INVESTIGATION INDICATED THAT ADDITIONAL REPAIRS WERE NOT REQUIRED BY MSD.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034801	WQTCBH	BULLITT HILLS WQTC	TANYARD BRANCH	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTCBH	233 MAYFLOWER RD	TANYARD BRANCH	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122121		6/27/2026 12:45:00 PM	OTTO		BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE- WATERS	06/27/26 07:20 PM	

Discharge Reporting:

Discharge Amount:	19,750 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

Notifications:

6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034169	WQTC2	HILLVIEW #2 WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTC2	376 NORWOOD DR	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4119862		6/22/2026 7:50:00 AM	OTTO		EXTERNAL INFLUENCE	6/27/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE- WATERS	06/22/26 12:30 PM	

Discharge Reporting:

Discharge Amount:	7,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE DITCH.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

Notifications:

6/22/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034169	WQTC2	HILLVIEW #2 WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTC2	376 NORWOOD DR	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122041		6/27/2026 5:04:00 AM	OTTO		EXTERNAL INFLUENCE	6/27/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE- WATERS	06/27/26 06:10 AM	

Discharge Reporting:

Discharge Amount:	1,650 GAL
Cause:	POWER OUTAGE (LG&E).
Clean Up:	MSD CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	LG&E RESTORED POWER.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034177	WQTC3	HILLVIEW #3 WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTC3	126 WESTERN RD	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4119045		6/18/2026 7:55:00 AM	OTTO		BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE- WATERS	06/18/26 10:50 AM	

Discharge Reporting:

Discharge Amount:	12,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP NEEDED AS BYPASS WAS EFF WATER THAT HAD BEEN THROUGH SCREENING, AERATION AND SECONDARY TREATMENT.
Control Zone:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP.
Impact:	NO DEBRIS OR SOLIDS WERE ON THE GROUND PRE DISINFECTION EFF WATER.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR TURNED OFF AIR TO KEEP SOLIDS FROM GOING OUT OF PLANT.
Public Notification:	SIGNS AT THE PLANT.

Notifications:

6/18/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/18/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/18/26 1:44 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/18/26 1:44 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034177	WQTC3	HILLVIEW #3 WQTC	BROOKS RUN	BULLITT

Facility Type	Facility ID	Facility Address	Receiving Stream	Discharge To
Sewer Treatment Plant	WQTC3	126 WESTERN RD	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122100		6/27/2026 11:45:00 AM	YARBROUGH		BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	06/27/26 07:00 PM	

Discharge Reporting:

Discharge Amount:	4,350 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0034185	WQTCPV	PIONEER VILLAGE #1 WQTC			BROOKS RUN		BULLITT				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Treatment Plant	WQTCPV	815 JOHN HARPER HWY					BROOKS RUN		STREAM		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4119049		6/18/2026 8:40:00 AM	OTTO		BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	06/18/26 01:10 PM	

Discharge Reporting:

Discharge Amount:	20,250 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

Notifications:

6/18/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/18/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/18/26 1:44 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/18/26 1:44 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0034185	WQTCPV	PIONEER VILLAGE #1 WQTC			BROOKS RUN		BULLITT				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Treatment Plant	WQTCPV	815 JOHN HARPER HWY					BROOKS RUN		STREAM		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4119943		6/22/2026 9:25:00 AM	HOWARD		BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	06/22/26 10:25 AM	

Discharge Reporting:

Discharge Amount:	600 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

Notifications:

6/22/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---



IMSAST0004
Overflow Report
6/1/2026 12:00:00 AM to 6/30/2026 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center			Recieving Steam of Discharge		Region				
KY0034185	WQTCPV	PIONEER VILLAGE #1 WQTC			BROOKS RUN		BULLITT				
Facility Type	Facility ID	Facility Address					Recieving Stream		Discharge To		
Sewer Treatment Plant	WQTCPV	815 JOHN HARPER HWY					BROOKS RUN		STREAM		
Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	4122093		6/27/2026 11:30:00 AM	OTTO		BEYOND APPROVED DESIGN STORM	6/27/2026 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	06/28/26 12:30 PM	

Discharge Reporting:

Discharge Amount:	19,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

Notifications:

6/27/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/27/26 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/28/26 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION
6/28/26 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
6/29/26 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV